

# SHENZHEN FUDIANKANG ENERGY CO., LTD

Tel:86-13729889887 Fax:86-20-84550026

Web: www.fdkenergy.com Email: info@fdkenergy.com

# **DATA SHEET**

**DIESEL GENERATOR 450KW** MODEL#FDK-CC450/H1 50HZ/1500RPM CUMMINS MODEL: KTA19-G4



#### **General Features:**

- All qualified generator sets are subjected to a comprehensive performance test which includes 50% load, 70% load, 100% load, 110% load and to check, verify that all control systems, alarm and shut-down protection.
- Equipped with battery charger and 24V high performance maintenance-free lead-acid starting batteries and connecting ٠ cables.
- Stainless galvanized zinc plates with strong corrosion-proof. ٠
- Vibration isolators between the engine/alternator and base frame.
- Equipped with industrial silencer and flexible exhaust hose.
- Designed to comply with ISO8528/GB2820.
- Powered by Cummins engine and coupled with Stamford alternator.
- Water jacket preheater, oil heater and double air cleaner, etc. are available.

FDR Diesei Generator Set	Dala		
Genset Model	FDK-CC450/H1	Engine Make	Cummins
Prime Power	400KW/500KVA	Engine Model	KTA19-G4
Standby Power	450KW/563KVA	Alternator model	Stamford HCI544D
Output Frequency / Rated speed	50Hz/1500rpm	Control System	DSE7320
Rated Voltage	230V/400V	Phase	Three

#### FDK Diesel Generator Set Data

(1) Prime power: The rating is available for an unlimited of annual operating hours in variable load applications, in accordance with ISO8528-1.A 10% overload is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046-1.


(2) Standby power: The rating is applicable for supplying emergency power in variable load applications for up to 200 hours per year in accordance with ISO8528-1. Overload is not allowed.

(3) Rated voltage: available with customer requirement.

#### Engine Specifications (DETAILED in APPENDIX)

		<u>.</u>		
Engine Model	KTA19-G4	Aspiration	Turbo-charged	
Engine Manufacturer	Cummins	Bore x Stroke (mm x mm)	159×159	
	(CCEC CHINA)	Displacement	18.9L	
Cylinder quantity	6	Compression Ratio	13.9:1	
Cylinder Arrangement	In-line	Prime power / Speed (KW/RPM)	448/1500	
Cycle	4	Standby power/ Speed (KW/RPM)	504/1500	
Cyclo			004/1000	

CE



FDK reserves the right to change the specifications and designs without noice.



### SHENZHEN FUDIANKANG ENERGY CO., LTD

Tel:86-13729889887 Fax:86-20-84550026 Web: www.fdkenergy.com Email: info@fdkenergy.com

Type Injection System	Direct injection
	Cummins PT
Piston Speed	7.9m/s
Friction Energy Output	45kw
Total Lubrication System Capacity (L)	50

		01		e 01
Fuel Consumption	at	100%	load	122 at 1500rpm
(L/HOUR)				
Starter motor				DC24V
Low idle				675-775rpm
Coolant Capacity (L)				30L

#### **Alternator Specifications**

HCI544D	Num
STAMFORD	Rate
Single bearing, Brushless,	
Self-excited	Pow
500KVA	Volta
1500 rpm	Insu
50Hz	Prot
	STAMFORD Single bearing, Brushless, Self-excited 500KVA 1500 rpm

Number of phase	3
Rated voltage	400V (Available with
	custom requirements)
Power factor	0.8
Voltage regulation NL-FL	≤±1%
Insulation grade	н
Protection grade	IP23

Alternator option: Leroy Somer, MECC, Marathon, Engga, Faraday

#### Control System DSE7320 (DETAILED in INSTRUCTION)

DSE7320 is an advanced control module based on micro-processor, containing all necessary functions for protection of the genset and the breaker control. It can monitor the mains supply, breaker control and automatically start the engine when the mains are abnormal. Accurately measure various operational parameters and display all values and alarms information on the LCD. In addition, the control module can automatically shut down the engine and indicate the engine failure.

#### FEATURES

- Microprocessor control, with high stability and credibility.
- Monitoring and measuring operational parameters of the mains supply and genset. ٠
- Indicating operation status, fault conditions, all parameters and alarms.
- Multiple protections; multiple parameters display, like pressure, temp. etc.
- Manual, automatic and remote work mode selectable.
- Real time clock for time and date display, overall runtime display, 250 log entries.
- Overall power output display.
- Integral speed/frequency detecting, telling status of start, rated operation, overspeed etc.
- Communication with PC via RS485 OR RS232 interface, using MODBUS protocol.

#### Soundproof Enclosure Specification

FDK silent generator is designed by professional acoustic engineers based on years of experience. Now we can make the noise of the generator less than 80-85dB(A) at 1m, or 70-75dB(A) at 7m, 60-65dB(A) at 15m.

#### **FEATURES**

- ٠ Multi-way air intake and exhaust guarantee the power performance of the generator.
- Large-scale impedance combined type silencer effectively reduce noise of the generator.
- Internal high performance rubber damper and flexible materials reduce vibration.
- Base mounted fuel tank supports the generator running for 8 hours.





ISO9001:2008 FDK reserves the right to change the specifications and designs without noice.



Tel:86-13729889887 Fax:86-20-84550026

Web: www.fdkenergy.com	Email: info@fdkenergy.com
------------------------	---------------------------

Op	tional						
Gen	Generator set Alternator		Low environment Temp		ATS	ATS	
	Open generator set		Stamford		Water heater		CHINT
	Silent generator set		Marathon		Oil heater		SCHNEIDER
	Trailer generator set		Mecc Alte		Battery heater		ABB
	ABB MCCB circuit breaker		Leroy Somer				
			Farady				
			Engga				
Fue	system	em Control system		Voltage		Synchronized system	
	12hrs base tank		AMF function		415/240V		CHINT Cabinet
	24hrs base tank		ATS control cabinet		400/230V		SCHNEIDER Cabinet
	Dual wall base fuel tank		DSE7320		380/220V		DSE8610 Module
	Outside fuel tank		DSE7510		220/127V		COMAQ Module
			GU620A		200/115V	П	DEIF Module

## **Dimension & Weight** Open

### Soundproof Version

Overall Size:	3200×1280×1950	Overall Size:	5100×1800×2350
L×W×H (mm)		L×W×H (mm)	
Weight (kg)	3650	Weight (kg)	5300
		Y	

#### **Sales Promises**


- FDK provides a full line of brand new and high quality products. Each and every unit is strictly factory tested before ۵ shipment.
- Quality warranty is according to our standard conditions: 12 months from BL date or 1000 running hours, whichever comes first.
- Service and parts are available from FDK or distributors in your location.
- FDK guarantee use BRAND NEW & GENUINE MACHINE.



Cummins	CHONGQING CUMN ENGINE COMPANY ENGINE PERFORMANCE	Ltd.	Basic Engine Model: KTA19-G4 Engine Critical Parts List: CPL: 4153	Curve Number: FR-4212 Date: 03JAN2004	Page No.
Displacement : <b>18.9</b> litre ( <b>1150</b> in <sup>3</sup> )		Bore : 1	59 mm (6.25 in.) Stroke : 159 mm	( <b>6.25</b> in.)	-1
No. of Cylinders : 6		Aspiratio	on : Turbocharged and Aftercoole	d	

1	Engine Speed	Standby Power		e Speed Standby Power Prime Power		Continuous Power	
	RPM	kWm	BHP	kWm	BHP	kWm	BHP
	1500	504	675	448	600	355	475
	1800	563	755	507	680	429	575

# Engine Performance Data @ 1500 RPM



# Engine Performance Data @ 1800 RPM

OUT	OUTPUT POWER			FUEL CONSUMPTION		ION	U.S. Gallons/hour 40.0
%	kWm	BHP	kg/ kWm∙h	lb/ BHP∙h	litre/ hour	U.S. Gal/ hour	35.0 <b>1800 RPM</b>
STAN	DBY PO	WER			•		30.0
100	563	755	0.206	0.338	136	35.9	25.0
PRIM	E POWE	R	•			•	20.0
100	507	680	0.205	0.337	122	32.3	15.0
75	380	510	0.210	0.346	94	24.8	10.0
50	254	340	0.218	0.355	65	17.0	
25	127	170	0.241	0.401	36	9.6	5.0
CONT	INUOUS	<b>POWE</b>	R				
100	429	575	0.207	0.340	104	27.5	0 100 200 300 400 500 600 700 Gross Engine Power Output - BHP

CONVERSIONS: (L

(Litres = U.S. Gal x 3.785)

(Engine kWm = BHP x 0.746)

(U.S. Gal = Litres x 0.2642)

(Engine BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

#### **CERTIFIED WITHIN 5%**



# POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

**STANDBY POWER RATING** is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

> This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

**<u>CONTINUOUS POWER RATING</u>** is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating. <u>PRIME POWER RATING</u> is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

#### UNLIMITED TIME RUNNING PRIME POWER

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

#### LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

#### **Reference Standards:**

BS-5514 and DIN-6271 standards are based on ISO-3046.

#### **Operation At Elevated Temperature And Altitude:**

The engine may be operated at:

1800 RPM up to 5,000 ft (1500 m) and  $104^{\circ}$  F ( $40^{\circ}$  C) without power deration.

1500 RPM up to 3,300 ft (1000 m) and 104° F (40° C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per  $10^{\circ}$  F (2% per  $11^{\circ}$  C).

	n <mark>mins Engine Compan</mark> gine Data Sheet	y Ltd.		
	ION NUMBER : D193091DX02	DATA SHEET : DS-4212-A DATE : 03JAN2004		
ENGINE MODEL : MTATJ-04 CONFIGURAT			IRVE: FR-4212	
INSTALLATION DIAGRAM     Fan to Flywheel : 3003983     Heat Exchanger Cooled :	CPL NUMBER • Engine Critical Parts List	: 4153		
GENERAL ENGINE DATA				
Туре		4 Cycle; In-line;	6 Cylinder Diesel	
Aspiration		Turbocharged a		
Bore x Stroke	— in x in (mm x mm)	6.25 x 6.25 (159	x 159)	
Displacement	— in <sup>3</sup> (liter)	1150 (18.9)		
Compression Ratio		13.9 : 1		
Dry Weight				
Fan to Flywheel Engine	— lb (kg)	4085	(1855)	
Heat Exchanger Cooled Engine	— lb (kg)	4572	(2076)	
Wet Weight				
Fan to Flywheel Engine	— lb (kg)	4245	(1927)	
Heat Exchanger Cooled Engine	— lb (kg)	4808	(2183)	
Memory of Inartia of Datating Components				
Moment of Inertia of Rotating Components  • with FW 4001 Flywheel	$h = 66^2 (k_0 = m^2)$	170	(7.2)	
		199	(7.2)	
with FW 4006 Flywheel Center of Gravity from Rear Face of Flywheel Housing (FH 40	$\frac{1}{10} = 10 \text{ m} \cdot 11 \text{ (kg} \cdot 11 \text{ )}$	28.4	(8.4)	
Center of Gravity above Crankshaft Centerline	, , , , , , , , , , , , , , , , , , , ,	28.4 9.0	(721) (229)	
Maximum Static Loading at Rear Main Bearing		2000	(908)	
Maximum Static Loading at Real Main Dearing	— ID (Kg)	2000	(900)	
ENGINE MOUNTING Maximum Bending Moment at Rear Face of Block	— lb ∙ ft (N • m)	1000	(1356)	
EXHAUST SYSTEM			(70)	
Maximum Back Pressure at Standby Power Rating	— in Hg (mm Hg)	3	(76)	
AIR INDUCTION SYSTEM				
Maximum Intake Air Restriction				
with Dirty Filter Element	— in H <sub>2</sub> O (mm H <sub>2</sub> O)	25	(635)	
with Normal Duty Air Cleaner and Clean Filter Element		10	(254)	
• with Heavy Duty Air Cleaner and Clean Filter Element		15	(381)	
		0.0	(20)	
Coolant Capacity — Engine Only		8.0	(30)	
— with HX 4073 Heat Exchanger	— US gai (liter)	17.5	(66)	
Maximum Coolant Friction Head External to Engine — 18	00 rpm — psi (kPa)	10	(69)	
=	00 rpm — psi (kPa)	8	(55)	
Maximum Static Head of Coolant Above Engine Crank Center		60	(18.3)	
Standard Thermostat (Modulating) Range		180 - 200	(82 - 93)	
Minimum Pressure Cap		10	(69)	
Maximum Top Tank Temperature for Standby / Prime Power		220 / 212	(104 / 100)	
Minimum Raw Water Flow @ 90°F to HX 4073 Heat Exchange		54	(204)	
Maximum Raw Water Inlet Pressure at HX 4073 Heat Exchar	ger — psi (kPa)	50	(345)	
LUBRICATION SYSTEM				
Oil Pressure @ Idle Speed	— nsi (kPa)	20	(138)	
@ Governed Speed	· · · · · · · · · · · · · · · · · · ·	50 - 70	(345 - 483)	
Maximum Oil Temperature	· · · · · · · · · · · · · · · · · · ·	250	(121)	
Oil Capacity with OP 4019 Oil Pan : High - Low		10 - 8.5	(38 - 32)	
Total System Capacity (Including Bypass Filter)		13.2	(50)	
		10.2	(00) 30°	
			30°	
•			30°	

www.fdkenergy.com

#### **FUEL SYSTEM**

Type Injection System	Direct Injection Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter	4.0 (102)
— with Dirty Fuel Filter	8.0 (203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.5 (165)
Maximum Fuel Flow to Injection Pump — US gph (liter / hr)	58 (220)

#### **ELECTRICAL SYSTEM**

Cranking Motor (Heavy Duty, Positive Engagement) — volt	24
Battery Charging System, Negative Ground — ampere	35
Maximum Allowable Resistance of Cranking Circuit	0.002
Minimum Recommended Battery Capacity	
• Cold Soak @ 50 °F (10 °C) and Above — 0°F CCA	600
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	640
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C) — 0°F CCA	900

#### PERFORMANCE DATA

All data is based on:
Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components.
Engine operating with fuel corresponding to grade No. 2-D per ASTM D975.
ISO 3046, Part 1, Standard Reference Conditions of: Barometric Pressure : 100 kPa (29.53 in Hg) Air Temperature : 25 °C (77 °F) Altitude : 110 m (361 ft) Relative Humidity : 30%

Steady State Stability Band at any Constant Load	+/- 0.25
Estimated Free Field Sound Pressure Level of a Typical Generator Set;	
Excludes Exhaust Noise; at Rated Load and 7.5 m (25 ft); 1800 rpm / 1500 rpm	91 / 89
Exhaust Noise at 1 m Horizontally from Centerline of Exhaust Pipe Outlet Upwards at 45°; 1800 rpm / 1500 rpm — dBA	119 / 118.5

Governed Engine Speed rpm	
Engine Idle Speed — rpm	
Gross Engine Power Output BHP (kW <sub>m</sub> )	
Brake Mean Effective Pressure psi (kPa)	
Piston Speed ft / min (m / s)	
Friction Horsepower HP (kW <sub>m</sub> )	
Engine Water Flow at Stated Friction Head External to Engine:	
• 3 psi Friction Head — US gpm (liter / s)	
Maximum Friction Head     US gpm (liter / s)	

#### Engine Data with Dry Type Exhaust Manifold

Intake Air Flow	cfm (liter / s)
Exhaust Gas Temperature	•°F (°C)
Exhaust Gas Flow	cfm (liter / s)
Air to Fuel Ratio	— air : fuel
Radiated Heat to Ambient	— BTU / min (kW <sub>m</sub> )
Heat Rejection to Coolant	— BTU / min (kW <sub>m</sub> )
Heat Rejection to Exhaust	BTU / min (kW <sub>m</sub> )

STANDBY			PRIME POWER				
60 hz 50 hz		60 hz		50 hz			
1	1800		1500		1800		500
675	5 - 775	675	- 775	67	5 - 775	675	- 775
755	(563)	675	(504)	680	(507)	600	(448)
287	(1979)	310	(2137)	260	(1793)	275	(1896)
1875	(9.5)	1562	(7.9)	1875	(9.5)	1562	(7.9)
85	(63)	60	(45)	85	(63)	60	(45)
196	(12.4)	162	(10.2)	196	(12.4)	162	(10.2)
175	(11.0)	145	(9.1)	175	(11.0)	145	(9.1)
1517	(716)	1226	(579)	1455	(687)	1126	(532)
939	(504)	1034	(557)	898	(481)	1000	(538)
3945	(1862)	3400	(1604)	3673	(1734)	3100	(1463)
25.5:1 22.5:1		2.5:1	27.2:1		23.2:1		
4700	(83)	4100	(72)	4200	(74)	3645	(64)
16350	(287)	15340	(270)	14350	(252)	13660	(240)
24000	(423)	20530	(361)	21500	(378)	18125	(319)
	. /		. /		` '		. /

N.A. - Data is Not Available

N/A - Not Applicable to this Engine

TBD - To Be Determined

ENGINE MODEL : KTA19-G4 DATA SHEET : DS-4212-A DATE : 03JAN04 CURVE NO. : FR-4212

CHONGQING CUMMINS ENGINE COMPANY Ltd. China Chongqing 400031

www.fdkenergy.com