

# SHENZHEN FUDIANKANG ENERGY CO., LTD

Tel:86-13729889887 Fax:86-20-84550026

Web: www.fdkenergy.com Email: info@fdkenergy.com

# **DATA SHEET**

**DIESEL GENERATOR 880KW** MODEL#FDK-CG880/H1 50HZ/1500RPM CUMMINS MODEL: KTA38-G5



### **General Features:**

- All qualified generator sets are subjected to a comprehensive performance test which includes 50% load, 70% load, 100% load, 110% load and to check, verify that all control systems, alarm and shut-down protection.
- Equipped with battery charger and 24V high performance maintenance-free lead-acid starting batteries and connecting cables.
- Stainless galvanized zinc plates with strong corrosion-proof.
- Vibration isolators between the engine/alternator and base frame.
- Equipped with industrial silencer and flexible exhaust hose.
- Designed to comply with ISO8528/GB2820.
- Powered by Cummins engine and coupled with Stamford alternator.
- Water jacket preheater, oil heater and double air cleaner, etc. are available.

FUR Diesei Generator Set i	Dala		
Genset Model	FDK-CG880/H1	Engine Make Cummins ON	
Prime Power	800KW/1000KVA	Engine Model	KTA38-G5
Standby Power	880KW/1100KVA	Alternator model	Stamford HCI634J
Output Frequency / Rated speed	50Hz/1500rpm	Control System	DSE7320
Rated Voltage	230V/400V	Phase	Three
- Hallou Follago	2001/1001		

#### FDK Diesel Generator Set Data

(1) Prime power: The rating is available for an unlimited of annual operating hours in variable load applications, in accordance with ISO8528-1.A 10% overload is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046-1.

(2) Standby power: The rating is applicable for supplying emergency power in variable load applications for up to 200 hours per year in accordance with ISO8528-1. Overload is not allowed.

(3) Rated voltage: available with customer requirement.

#### Engine Specifications (DETAILED in APPENDIX)

Engine Model	KTA38-G5	Aspiration	Turbo-charged	
Engine Manufacturer	Cummins	Bore x Stroke (mm x mm)	159×159	
	ORIGINAL INDIA	Displacement	37.8L	
Cylinder quantity	12	Compression Ratio	13.9:1	
Cylinder Arrangement	60° Vee	Prime power / Speed (KW/RPM)	880kw/1500	
Cycle	4	Standby power/ Speed (KW/RPM)	970kw/1500	

CE

ISO9001:2008

FDK reserves the right to change the specifications and designs without noice.



### SHENZHEN FUDIANKANG ENERGY CO., LTD

# GUANGZHOU SANQ DIESEL GENERATOR SET CO., LTD

Tel:86-13729889887 Fax:86-20-84550026 Web: www.fdkenergy.com Email: info@fdkenergy.com

Type Injection System	Cummins PT
	Direct Injection
Piston Speed	7.9m/s
Friction Energy Output	86kw
Total Lubrication System Capacity	135L

Fuel Consumption at 100% load	202 at 1500rpm
(g/KWh)	
Starter motor	DC24V
Low idle	725-775pm
Coolant Capacity (L)	129

#### **Alternator Specifications**

Alternator model	HCI634J	Number of phase	3
Alternator manufacturer	STAMFORD	Rated voltage	400V (Available with
Exciter type	Single bearing, Brushless,		custom requirements)
	Self-excited	Power factor	0.8
Rated output prime power	1000KVA	Voltage regulation NL-FL	≤±1%
Rated speed	1500 rpm	Insulation grade	н
Rated frequency	50Hz	Protection grade	IP23
	· · · · · · · · · · · · · · · · · · ·		

Alternator option: Leroy Somer, MECC, Marathon, Engga, Faraday

### Control System DSE7320 (DETAILED in INSTRUCTION)

DSE7320 is an advanced control module based on micro-processor, containing all necessary functions for protection of the genset and the breaker control. It can monitor the mains supply, breaker control and automatically start the engine when the mains are abnormal. Accurately measure various operational parameters and display all values and alarms information on the LCD. In addition, the control module can automatically shut down the engine and indicate the engine failure.

#### FEATURES

- Microprocessor control, with high stability and credibility.
- Monitoring and measuring operational parameters of the mains supply and genset.
- Indicating operation status, fault conditions, all parameters and alarms.
- Multiple protections; multiple parameters display, like pressure, temp. etc.
- Manual, automatic and remote work mode selectable.
- Real time clock for time and date display, overall runtime display, 250 log entries.
- Overall power output display.
- Integral speed/frequency detecting, telling status of start, rated operation, overspeed etc.
- Communication with PC via RS485 OR RS232 interface, using MODBUS protocol.

### Soundproof Enclosure Specification

FDK silent generator is designed by professional acoustic engineers based on years of experience. Now we can make the noise of the generator less than 80-85dB(A) at 1m, or 70-75dB(A) at 7m, 60-65dB(A) at 15m.

#### FEATURES

- Multi-way air intake and exhaust guarantee the power performance of the generator.
- Large-scale impedance combined type silencer effectively reduce noise of the generator.
- Internal high performance rubber damper and flexible materials reduce vibration.
- Base mounted fuel tank supports the generator running for 8 hours.





ISO9001:2008 FDK reserves the right to change the specifications and designs without noice.



#### SHENZHEN FUDIANKANG ENERGY CO., LTD

Tel:86-13729889887 Fax:86-20-84550026

Web: www.fdkenergy.com Email: info@fdkenergy.com

Op	Optional								
Gen	Generator set		rnator	Low	environment Temp	ATS			
	Open generator set		Stamford		Water heater		CHINT		
	Silent generator set		Marathon		Oil heater		SCHNEIDER		
	Trailer generator set		Mecc Alte		Battery heater		ABB		
	ABB MCCB circuit breaker	□ Leroy Somer							
			Farady						
			Engga						
Fue	system	Control system		Voltage		Synchronized system			
	12hrs base tank		AMF function		415/240V		CHINT Cabinet		
	24hrs base tank		ATS control cabinet		400/230V		SCHNEIDER Cabinet		
	Dual wall base fuel tank		□ DSE7320		380/220V		DSE8610 Module		
	Outside fuel tank		DSE7510		220/127V		COMAQ Module		
			GU620A		200/115V		DEIF Module		

# **Dimension & Weight** Open

### Soundproof Version

Overall Size:	4200×1820×2350	· · ·	Overall Size:	6000×2300×2550
L×W×H (mm)			L×W×H (mm)	
Weight (kg)	7800		Weight (kg)	9800
			Y	

### **Sales Promises**

- FDK provides a full line of brand new and high quality products. Each and every unit is strictly factory tested before ۵ shipment.
- Quality warranty is according to our standard conditions: 12 months from BL date or 1000 running hours, whichever comes first.
- Service and parts are available from FDK or distributors in your location.
- FDK guarantee use BRAND NEW & GENUINE MACHINE.



ummins	CUMMINS ENGINE COM	IPANY, INC	Basic Engine Model: <b>KTA38-G5</b>	Curve Number: FR-6140	Page No.
cun	Columbus, Indiana 47201 ENGINE PERFORMANCE CURVE		Engine Critical Parts List: CPL: 1543	Date: 02Sep98	-
Displacement : <b>37.8</b> litre ( <b>2300</b> in <sup>3</sup> ) Bore : <b>1</b>		Bore : 159	9 mm (6.25 in.) Stroke : 159 mm (	( <b>6.25</b> in.)	
No. of Cylinders : 12 Aspirat		Aspiration	: Turbocharged and Aftercoole	d	

Engine Speed	Standb	y Power	Prime	Power	Continuous Power	
RPM	kWm BHP		kWm	BHP	kWm	BHP
1500	970	1300	880	1180	656	880
1800						

# Engine Performance Data @ 1500 RPM

OUT		WER	F		SUMPTI	ON	
%	kWm	BHP	kg/ kWm∙h	lb/ BHP∙h	litre/ hour	U.S. Gal/ hour	200.0 1500 RPM
STAN	DBY PO	WER					
100	970	1300	0.200	0.329	228	60.3	
PRIM	E POWE	R					
100	880	1180	0.202	0.332	209	55.1	
75	660	885	0.207	0.341	161	42.5	50.0
50	440	590	0.218	0.360	113	29.9	
25	220	295	0.251	0.416	65	17.3	
CONT	INUOUS	S POWE	R				0 100 200 300 400 500 600 700 800 900 1000
100	656	880	0.204	0.336	158	41.7	Gross Engine Power Output - kWm

# Engine Performance Data @ 1800 RPM

Not Available at 1800 RPM	Not Available at 1800 RPM

CONVERSIONS: (Litres = U.S. Gal x 3.785)

 $(kWm = BHP \times 0.746)$ 

(U.S. Gal = Litres x 0.2642)

(BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

DK. Inueblood

**CHIEF ENGINEER** www.fdkenergy.com

**CERTIFIED WITHIN 5%** 

# POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

> This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

<u>CONTINUOUS POWER RATING</u> is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating. <u>PRIME POWER RATING</u> is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

#### UNLIMITED TIME RUNNING PRIME POWER

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

#### LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

#### **Reference Standards:**

BS-5514 and DIN-6271 standards are based on ISO-3046.

#### **Operation At Elevated Temperature And Altitude:**

The engine may be operated at:

1500 RPM up to 5,000 ft. (1525 m) and 104° F (40° C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per  $10^{\circ}$  F (2% per  $11^{\circ}$  C).

Cummins Engine Engine Dat	• •		
ENGINE MODEL : KTA38-G5 CONFIGURATION NUMB	BER : D233031DX02		EET : DS-4891-A ATE : 02Sep98
		RFORMANCE CU	
	CPL NUMBER • Engine Critical Parts List	: 1543	
GENERAL ENGINE DATA			
Туре			; 12-Cylinder Diesel
Aspiration		Turbocharged a	
Bore x Stroke		6.25 x 6.25 (159	x 159)
Displacement		2300 (37.8)	
Compression Ratio		13.9 : 1	
Dry Weight			
Fan to Flywheel Engine	— lb (kg)	9482	(4300)
Heat Exchanger Cooled Engine		9923	(4500)
Wet Weight			
Fan to Flywheel Engine	— lb (kg)	10002	(4536)
Heat Exchanger Cooled Engine	— lb (kg)	10602	(4808)
Moment of Inertia of Rotating Components <ul> <li>with FW 6001 Flywheel</li> </ul>	$lb = \frac{42}{2} (lc - 2)$	040	(10.4)
with FW 6001 Flywheel     with FW 6011 Flywheel		248	(10.4)
Center of Gravity from Rear Face of Flywheel Housing (FH 6024)		493 38.6	(20.8) (980)
Center of Gravity Above Crankshaft Centerline		11.0	(279)
Maximum Static Loading at Rear Main Bearing		2000	(908)
ENGINE MOUNTING Maximum Bending Moment at Rear Face of Block EXHAUST SYSTEM Maximum Back Pressure		4500 3	(6100)
	— III Hy (IIIII Hy)	3	(76)
AIR INDUCTION SYSTEM			
Maximum Intake Air Restriction			
with Dirty Filter Element	— in $H_2O$ (mm $H_2O$ )	25	(635)
with Normal Duty Air Cleaner and Clean Filter Element	— in $H_2^-O$ (mm $H_2^-O$ )	10	(254)
with Heavy Duty Air Cleaner and Clean Filter Element	— in $H_2O$ (mm $H_2O$ )	15	(381)
COOLING SYSTEM			
		20.7	(404)
Coolant Capacity — Engine Only — with HX 6076 Heat Exchanger		32.7 52.7	(124) (199)
		52.1	(199)
Maximum Coolant Friction Head External to Engine — 1800 rpm	— psi (kPa)	N/A	N/A
	— psi (kPa)	7	(48)
Maximum Static Head of Coolant Above Engine Crank Centerline		60	(18.3)
Standard Thermostat (Modulating) Range		180 - 200	(82 - 93)
Minimum Pressure Cap	— psi (kPa)	10	(69)
Maximum Top Tank Temperature for Standby / Prime Power		220 / 212	(104 / 100)
Minimum Raw Water Flow @ 90°F to HX 6076 Heat Exchanger	— US gpm (liter / min)	108	(409)
Maximum Raw Water Inlet Pressure at HX 6076 Heat Exchanger	— psi (kPa)	50	(345)
LUBRICATION SYSTEM			
Oil Pressure @ Idle Speed		20	(138)
@ Governed Speed	— psi (kPa)	45 - 65	(310 - 448)
Maximum Oil Temperature		250	(121)
Oil Capacity with OP 6023 Oil Pan : High - Low		30 - 23	(114 - 87)
Total System Capacity (Including Bypass Filter)		35.7	(135)
Angularity of OP 6023 Oil Pan — Front Down			30°
— Front Up			30° 20°
— Side to Side			30°

# www.fdkenergy.com

### FUEL SYSTEM

FUEL SYSTEM		
Type Injection System	Direct Injection	Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter	4.0	(102)
— with Dirty Fuel Filter	8.0	(203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.5	(165)
Maximum Fuel Flow to Injection Pump — US gph (liter / hr)	113	(428)
ELECTRICAL SYSTEM		
Cranking Motor (Heavy Duty, Positive Engagement) wolt	24	
Battery Charging System, Negative Ground — ampere	35	
Maximum Allowable Resistance of Cranking Circuit ohm	0.002	
Minimum Recommended Battery Capacity		
• Cold Soak @ 50 °F (10 °C) and Above — 0°F CCA	1200	
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	1280	
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C)	1800	
COLD START CAPABILITY		
Minimum Ambient Temperature for Aided (with Coolant Heater) Cold Start within 10 seconds	50	(10)
Minimum Ambient Temperature for Unaided Cold Start	45	(7)
		( )
PERFORMANCE DATA		
All data is based on:• Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components. • Engine operating with fuel corresponding to grade No. 2-D per ASTM D975. • ISO 3046, Part 1, Standard Reference Conditions of: Barometric Pressure : 100 kPa (29.53 in Hg) Alti Temperature : 25 °C (77 Altitude : 110 m (361 ft)Air Temperature : 30%	°F)	

Steady State Stability Band at any Constant Load	+/- 0.25
Estimated Free Field Sound Pressure Level of a Typical Generator Set;	
Excludes Exhaust Noise; at Rated Load and 7.5 m (24.6 ft); [1500 RPM]	N.A.
Exhaust Noise at 0.1 m Horizontally from Centerline of Exhaust Pipe Outlet Upwards at 45° [1500 RPM]	N.A.

Governed Engine Speed rpm
Engine Idle Speed mpm
Gross Engine Power Output BHP (kW <sub>m</sub> )
Brake Mean Effective Pressure psi (kPa)
Piston Speed ft / min (m / s)
Friction Horsepower — HP (kW <sub>m</sub> )
Engine Water Flow at Stated Friction Head External to Engine:
• 4 psi Friction Head — US gpm (liter / s)
Maximum Friction Head     With the main of t

#### Engine Data with Dry Type Exhaust Manifold

Intake Air Flow	— cfm (liter / s)
Exhaust Gas Temperature	°F (°C)
Exhaust Gas Flow	cfm (liter / s)
Air to Fuel Ratio	— air : fuel
Radiated Heat to Ambient	— BTU / min (kW <sub>m</sub> )
Heat Rejection to Coolant	— BTU / min (kW <sub>m</sub> )
Heat Rejection to Exhaust	— BTU / min (kW <sub>m</sub> )

<u>STA</u>	ANDBY		PRIME	POWER		
60 hz	50 hz		60 hz	50 hz		
Not Applicable for 60 Hz Operation		500 - 775 (970) (2055) (7.9) (86) (19.6) (17.7) (1213) (513) (3306) 5 : 1 (137) (594) (590)	Not Applicable for 60 Hz Operation	725 1180 271 1562 115 310 280 2415 930 6465	(499) (3051) 5.1 : 1	

N.A. - Data is Not Available

N/A - Not Applicable to this Engine

TBD - To Be Determined

CUMMINS ENGINE COMPANY, INC.

ENGINE MODEL : KTA38-G5 DATA SHEET : DS-4891-A DATE : 02Sep98 CURVE NO. : FR-6140