

## GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995 Email: info@fdkenergy.com

Web: www.fdkenergy.com

## **DATA SHEET**

DIESEL GENERATOR 1000KW

MODEL#FDK-CC1250/H2

60HZ/1800RPM

**CUMMINS MODEL: KTA38-G4** 



#### **General Features:**

- All qualified generator sets are subjected to a comprehensive performance test which includes 50% load, 70% load, 100% load, 110% load and to check, verify that all control systems, alarm and shut-down protection.
- Equipped with battery charger and 24V high performance maintenance-free lead-acid starting batteries and connecting cables
- Stainless galvanized zinc plates with strong corrosion-proof.
- Vibration isolators between the engine/alternator and base frame.
- Equipped with industrial silencer and flexible exhaust hose.
- Designed to comply with ISO8528/GB2820.
- Powered by Cummins engine and coupled with Stamford alternator.
- Water jacket preheater, oil heater and double air cleaner, etc. are available.

#### **FDK Diesel Generator Set Data**

FDK-CC1250/H2
900KW/1125KVA
1000KW/1250KVA
60Hz/1800rpm
230V/400V

Engine Make	Cummins CHINA
Engine Model	KTA38-G4
Alternator model	Stamford HCl634J
Control System	DSE7320
Phase	Three

- (1) **Prime power**: The rating is available for an unlimited of annual operating hours in variable load applications, in accordance with ISO8528-1.A 10% overload is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046-1.
- (2) **Standby power**: The rating is applicable for supplying emergency power in variable load applications for up to 200 hours per year in accordance with ISO8528-1. Overload is not allowed.
- (3) Rated voltage: available with customer requirement.

#### Engine Specifications (DETAILED in APPENDIX)

Engine Model	KTA38-G4
Engine Manufacturer	Cummins
	CHINA CCEC
Cylinder quantity	12
Cylinder Arrangement	60° Vee;
Cycle	4

Aspiration	Turbo-charged
Bore x Stroke (mm x mm)	159×159
Displacement	37.8L
Compression Ratio	13.9:1
Prime power / Speed (KW/RPM)	1007kw/1800
Standby power/ Speed (KW/RPM)	1112kw/1800







#### **GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD** SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995

		Web: www.fdkenergy.com Em	ail: info@fdkenergy.com
Type Injection System	Direct Injection	Fuel Consumption at 100% load (L/H)	245 at 1800rpm
	Cummins PT	Starter motor	24V
Piston Speed	9.5m/s	Low idle	725-775pm
Friction Energy Output	127kw	Coolant Capacity (L)	124
Total Lubrication System Capacity (L)	135		

#### **Alternator Specifications**

•			
Alternator model	HCl634J Number of phase		3
Alternator manufacturer	STAMFORD	TAMFORD Rated voltage	
Exciter type	Single bearing, Brushless,		custom requirements)
	Self-excited	Power factor	0.8
Rated output prime power	1300KVA	Voltage regulation NL-FL	≤±1%
Rated speed	1800 rpm	Insulation grade	Н
Rated frequency	60Hz	Protection grade	IP23

Alternator option: Leroy Somer, MECC, Marathon, Engga, Faraday

#### Control System DSE7320 (DETAILED in INSTRUCTION)

DSE7320 is an advanced control module based on micro-processor, containing all necessary functions for protection of the genset and the breaker control. It can monitor the mains supply, breaker control and automatically start the engine when the mains are abnormal. Accurately measure various operational parameters and display all values and alarms information on the LCD. In addition, the control module can automatically shut down the engine and indicate the engine failure.

#### **FEATURES**

- Microprocessor control, with high stability and credibility.
- Monitoring and measuring operational parameters of the mains supply and genset.
- Indicating operation status, fault conditions, all parameters and alarms.
- Multiple protections; multiple parameters display, like pressure, temp. etc.
- Manual, automatic and remote work mode selectable.
- Real time clock for time and date display, overall runtime display, 250 log entries.
- Overall power output display.
- Integral speed/frequency detecting, telling status of start, rated operation, overspeed etc.
- Communication with PC via RS485 OR RS232 interface, using MODBUS protocol.

#### **Soundproof Enclosure Specification**

FDK silent generator is designed by professional acoustic engineers based on years of experience. Now we can make the noise of the generator less than 80-85dB(A) at 1m, or 70-75dB(A) at 7m, 60-65dB(A) at 15m.

- Multi-way air intake and exhaust guarantee the power performance of the generator.
- Large-scale impedance combined type silencer effectively reduce noise of the generator.
- Internal high performance rubber damper and flexible materials reduce vibration.
- Base mounted fuel tank supports the generator running for 8 hours.







## GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995

Web: www.fdkenergy.com Email: info@fdkenergy.com

#### **Optional**

Ger	Generator set		rnator	Low environment Te		ATS	
	Open generator set		Stamford		Water heater		CHINT
	Silent generator set		Marathon		Oil heater		SCHNEIDER
	Trailer generator set		Mecc Alte		Battery heater		ABB
	ABB MCCB circuit breaker		Leroy Somer				
			Farady				
			Engga				
Fue	system Control system Voltage		Control system		age	Syn	chronized system
	12hrs base tank		AMF function		415/240V		CHINT Cabinet
	24hrs base tank		ATS control cabinet		400/230V		SCHNEIDER Cabinet
	Dual wall base fuel tank		DSE7320		380/220V		DSE8610 Module
	Outside fuel tank		DSE7510		220/127V		COMAQ Module
			GU620A		200/115V	П	DEIF Module

## Dimension & Weight Open

Overall Size:	4200×1820×2300
L×W×H (mm)	
Weight (kg)	8200

#### **Soundproof Version**

Overall Size:	20FT CONTAINER
L×W×H (mm)	
Weight (kg)	12500

#### **Sales Promises**

- ◆ FDK provides a full line of brand new and high quality products. Each and every unit is strictly factory tested before shipment.
- Quality warranty is according to our standard conditions: 12 months from BL date or 1000 running hours, whichever comes
- Service and parts are available from FDK or distributors in your location.
- ◆ FDK guarantee use **BRAND NEW & GENUINE MACHINE**.







## CHONGQING CUMMINS ENGINE COMPANY Ltd.

**ENGINE PERFORMANCE CURVE** 

Basic Engine Model: KTA38-G4

Curve Number: FR-6138

Date:

Page No.

Engine Critical Parts List:

CPL: 1542

03JAN2004

Displacement : **37.8** litre (**2300** in $^3$ ) Bore : **159** mm (**6.25** in.) Stroke : **159** mm (**6.25** in.)

No. of Cylinders: 12 Aspiration: Turbocharged and Aftercooled

Engine Speed	Standby	y Power	Prime Power		Continuo	us Power
RPM	kWm	ВНР	kWm	ВНР	kWm	ВНР
1500						
1800	1112	1490	1007	1350	776	1040


### Engine Performance Data @ 1500 RPM

Not Available at 1500 RPM

Not Available at 1500 RPM

#### **Engine Performance Data @ 1800 RPM**

OUTPUT POWER			FUEL CONSUMPTION				
%	kWm	ВНР	kg/ kWm∙h			U.S. Gal/ hour	
STAN	STANDBY POWER						
100	1112	1490	0.207	0.341	271	71.5	
PRIME	POWE	R					
100	1007	1350	0.207	0.340	245	64.6	
75	755	1012	0.214	0.351	190	50.1	
50	504	675	0.229	0.379	136	36.0	
25	252	338	0.273	0.452	81	21.5	
CONT	INUOUS	POWE	ER .				
100	776	1040	0.212	0.348	193	51.0	



**CONVERSIONS:** 

(Litres = U.S. Gal x 3.785)

 $(kWm = BHP \times 0.746)$ 

(U.S. Gal = Litres x 0.2642)

(BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

TECHNICAL DATA DEPT. CERTIFIED WITHIN 5% CHIEF ENGINEER

# POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

CONTINUOUS POWER RATING is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

PRIME POWER RATING is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

#### **UNLIMITED TIME RUNNING PRIME POWER**

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

#### **LIMITED TIME RUNNING PRIME POWER**

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

#### Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

#### **Operation At Elevated Temperature And Altitude:**

The engine may be operated at:

1800 RPM up to 5,000 ft. (1525 m) and 104 $^{\rm o}$  F (40 $^{\rm o}$  C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per 10° F (2% per 11° C).

## **Chongqing Cummins Engine Company Ltd.**

#### **Engine Data Sheet**

DATA SHEET: DS-4890-A
DATE: 03JAN2004
PERFORMANCE CURVE: FR-6138 **ENGINE MODEL: KTA38-G4 CONFIGURATION NUMBER:** D233031DX02

INSTALLATION DIAGRAM

• Fan to Flywheel : 3383897

• Heat Exchanger Cooled :

**CPL NUMBER** • Engine Critical Parts List

: 1542

Туре		4-Cycle; 60° Ve	
Aspiration		Turbocharged a	
Bore x Stroke	— in x in (mm x mm)	6.25 x 6.25 (159	x 159)
Displacement	— in <sup>3</sup> (liter)	2300 (37.8)	
Compression Ratio		13.9 : 1	
Dry Weight			
Fan to Flywheel Engine	— lb (kg)	9482	(4300)
Heat Exchanger Cooled Engine	— lb (kg)	9923	(4500)
Wet Weight	, 5,		, ,
Fan to Flywheel Engine	— lb (kg)	10002	(4536)
Heat Exchanger Cooled Engine	— lb (kg)	10602	(4808)
Moment of Inertia of Rotating Components			
with FW 6001 Flywheel	— lb <sub>m</sub> • ft <sup>2</sup> (kg • m <sup>2</sup> )	248	(10.4)
• with FW 6011 Flywheel		493	(20.8)
Center of Gravity from Rear Face of Flywheel Housing (FH 6024)		38.6	(980)
Center of Gravity above Crankshaft Centerline		11.0	(279)
Maximum Static Loading at Rear Main Bearing		2000	(908)
		2000	(000)
ENGINE MOUNTING  Maximum Bending Moment at Rear Face of Block	— lh • ft (N • m)	4500	(6100)
		1000	(0100)
XHAUST SYSTEM  Maximum Back Pressure	in Ha (mm Ha)	3	(76)
IVIAAIITIUITI DACK FTESSUIE		3	(76)
AIR INDUCTION SYSTEM			
Maximum Intake Air Restriction			
with Dirty Filter Element		25	(635)
with Normal Duty Air Cleaner and Clean Filter Element	— in H <sub>2</sub> O (mm H <sub>2</sub> O)	10	(254)
with Heavy Duty Air Cleaner and Clean Filter Element	— in $H_2O$ (mm $H_2O$ )	15	(381)
COOLING SYSTEM			
Coolant Capacity — Engine Only	— US gal (liter)	32.7	(124)
— with HX 6076 Heat Exchanger		52.7	(199)
Maximum Coolant Friction Head External to Engine — 1800 rpm	— psi (kPa)	10	(69)
	— psi (kPa)		N/A
Maximum Static Head of Coolant Above Engine Crank Centerline		60	(18.3)
Standard Thermostat (Modulating) Range		180 - 200	(82 - 93)
	`_ (	4.0	(69)
Minimum Pressure Cap  Maximum Top Tank Temperature for Standby / Prime Power		220 / 212	
		220 / 212	(104 / 100)
Minimum Raw Water Flow @ 90°F to HX 6076 Heat Exchanger		108	(409)
Maximum Raw Water Inlet Pressure at HX 6076 Heat Exchanger	— psi (kra)	50	(345)
LUBRICATION SYSTEM			
Oil Pressure @ Idle Speed	,	20	(138)
@ Governed Speed		45 - 65	(310 - 448)
Maximum Oil Temperature		250	(121)
Oil Capacity with OP 6023 Oil Pan: High - Low	— US gal (liter)	30 - 23	(114 - 87)
Total System Capacity (Including Bypass Filter)	— US gal (liter)	35.7	(135)
Angularity of OP 6023 Oil Pan — Front Down			30°
			30°
— Front Up			00

#### **FUEL SYSTEM**

Type Injection System	Direct Injection	Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter — in Hg (mm Hg)	4.0	(102)
— with Dirty Fuel Filter — in Hg (mm Hg)	8.0	(203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.5	(165)
Maximum Fuel Flow to Injection Pump	134	(507)
ELECTRICAL SYSTEM		
Cranking Motor (Heavy Duty, Positive Engagement)	24	
Battery Charging System, Negative Ground — ampere	35	
Maximum Allowable Resistance of Cranking Circuit — ohm	0.002	
Minimum Recommended Battery Capacity		
• Cold Soak @ 50 °F (10 °C) and Above	1200	
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	1280	
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C)	1800	

#### **PERFORMANCE DATA**

All data is based on:

- Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components.
- Engine operating with fuel corresponding to grade No. 2-D per ASTM D975.
- ISO 3046, Part 1, Standard Reference Conditions of:

Barometric pressure : 100 kPa (29.53 in Hg) Air Temperature :  $25^{\circ}\text{C}$  (77°F) Altitude : 110 m (361 ft) Relative Humidity : 30%

Governed Engine Speedrpm
Engine Idle Speed — rpm
Gross Engine Power Output BHP (kW <sub>m</sub> )
Brake Mean Effective Pressure psi (kPa)
Piston Speed—ft / min (m / s)
Friction Horsepower — HP (kW <sub>m</sub> )
Engine Water Flow at Stated Friction Head External to Engine:
• 4 psi Friction Head — US gpm (liter / s)
Maximum Friction Head — US gpm (liter / s)

4 psi Friction Head	— US gpm (liter / s)
Maximum Friction Head	— US gpm (liter / s)
<b>Engine Data with Dry Type Exhaust</b>	<u>Manifold</u>
Intake Air Flow	cfm (liter / s)
Exhaust Gas Temperature	°F (°C)
Exhaust Gas Flow	cfm (liter / s)
Air to Fuel Ratio	— air : fuel
Radiated Heat to Ambient	BTU / min (kW <sub>m</sub> )

Heat Rejection to Coolant ...... BTU / min  $(kW_m)$  Heat Rejection to Exhaust ..... BTU / min  $(kW_m)$ 

<u>STANDBY</u>		PRIME POWER	
60 hz 50 hz		60 hz 50 hz	
1800 725 - 775 1490 (1112) 285 (1965) 1875 (9.5) 170 (127) 390 (24.6) 340 (21.4) 3040 (1435) 975 (524) 8405 (3967) 26.4 : 1 9275 (163) 38740 (681) 43365 (762)	Not Applicable for 50 Hz Operation	1800 725 - 775 1350 (1007) 258 (1779) 1875 (9.5) 170 (127) 390 (24.6) 340 (21.4) 2880 (1359) 930 (499) 7715 (3641) 27.7:1 8420 (148) 35100 (617) 39510 (694)	1401

N.A. - Data is Not Available

N/A - Not Applicable to this Engine

TBD - To Be Determined

ENGINE MODEL: KTA38-G4
DATA SHEET: DS-4890-A

DATE: 03JAN04 CURVE NO.: FR-6138