

GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995 Email: info@fdkenergy.com

Web: www.fdkenergy.com E


DATA SHEET

DIESEL GENERATOR 200KW

MODEL#FDK-CC250/H1

50HZ/1500RPM

CUMMINS MODEL: NT855-GA



General Features:

- All qualified generator sets are subjected to a comprehensive performance test which includes 50% load, 70% load, 100% load, 110% load and to check, verify that all control systems, alarm and shut-down protection.
- Equipped with battery charger and 24V high performance maintenance-free lead-acid starting batteries and connecting cables
- Stainless galvanized zinc plates with strong corrosion-proof.
- Vibration isolators between the engine/alternator and base frame.
- Equipped with industrial silencer and flexible exhaust hose.
- Designed to comply with ISO8528/GB2820.
- Powered by Cummins engine and coupled with Stamford alternator.
- Water jacket preheater, oil heater and double air cleaner, etc. are available.

FDK Diesel Generator Set Data

Genset Model	FDK-CC250/H1
Prime Power	180KW/225KVA
Standby Power	200KW/250KVA
Output Frequency / Rated speed	50Hz/1500rpm
Rated Voltage	230V/400V

Engine Make	Cummins
Engine Model	NT855-GA
Alternator model	Stamford UCDI274J
Control System	DSE7320
Phase	Three

- (1) **Prime power**: The rating is available for an unlimited of annual operating hours in variable load applications, in accordance with ISO8528-1.A 10% overload is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046-1.
- (2) **Standby power**: The rating is applicable for supplying emergency power in variable load applications for up to 200 hours per year in accordance with ISO8528-1. Overload is not allowed.
- (3) Rated voltage: available with customer requirement.

Engine Specifications (DETAILED in APPENDIX)

Engine Model	NT855-GA
Engine Manufacturer	Cummins
	(CCEC CHINA)
Cylinder quantity	6
Cylinder Arrangement	In-line
Cycle	4

Aspiration	Turbo-charged
Bore x Stroke (mm x mm)	140×152
Displacement	14L
Compression Ratio	15.0:1
Prime power / Speed (KW/RPM)	231/1500
Standby power/ Speed (KW/RPM)	254/1500







GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995

		Web: www.fdkenergy.com Em	Email: info@fdkenergy.com	
Type Injection System	Direct injection	Fuel Consumption at 100% load	53 at 1500rpm	
	Cummins PT	(L/HOUR)		
Piston Speed	7.62m/s	Starter motor	DC24V	
Friction Energy Output	22kw	Low idle	575-650rpm	
Total Lubrication System Capacity (L)	38.6	Coolant Capacity (L)	20.8L	

Alternator Specifications

•			
Alternator model	UCDI274K	Number of phase	3
Alternator manufacturer	STAMFORD	Rated voltage	400V (Available wi
Exciter type	Single bearing, Brushless,		custom requirements)
	Self-excited	Power factor	0.8
Rated output prime power	250KVA	Voltage regulation NL-FL	≤±1%
Rated speed	1500 rpm	Insulation grade	Н
Rated frequency	50Hz	Protection grade	IP23

Alternator option: Leroy Somer, MECC, Marathon, Engga, Faraday

Control System DSE7320 (DETAILED in INSTRUCTION)

DSE7320 is an advanced control module based on micro-processor, containing all necessary functions for protection of the genset and the breaker control. It can monitor the mains supply, breaker control and automatically start the engine when the mains are abnormal. Accurately measure various operational parameters and display all values and alarms information on the LCD. In addition, the control module can automatically shut down the engine and indicate the engine failure.

FEATURES

- Microprocessor control, with high stability and credibility.
- Monitoring and measuring operational parameters of the mains supply and genset.
- Indicating operation status, fault conditions, all parameters and alarms.
- Multiple protections; multiple parameters display, like pressure, temp. etc.
- Manual, automatic and remote work mode electable.
- Real time clock for time and date display, overall runtime display, 250 log entries.
- Overall power output display.
- Integral speed/frequency detecting, telling status of start, rated operation, over speed etc.
- Communication with PC via RS485 OR RS232 interface, using MODBUS protocol.

Soundproof Enclosure Specification

FDK silent generator is designed by professional acoustic engineers based on years of experience. Now we can make the noise of the generator less than 80-85dB(A) at 1m, or 70-75dB(A) at 7m, 60-65dB(A) at 15m.

FEATURES

- Multi-way air intake and exhaust guarantee the power performance of the generator.
- Large-scale impedance combined type silencer effectively reduce noise of the generator.
- Internal high performance rubber damper and flexible materials reduce vibration.
- Base mounted fuel tank supports the generator running for 8 hours.







GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995

Web: www.fdkenergy.com Email: info@fdkenergy.com

Optional

Ger	erator set	Alte	rnator	Low environment Temp		ATS	
	Open generator set		Stamford		Water heater		CHINT
	Silent generator set		Marathon		Oil heater		SCHNEIDER
	Trailer generator set		Mecc Alte		Battery heater		ABB
	ABB MCCB circuit breaker		Leroy Somer				
			Farady				
			Engga				
Fue	system	Control system		Voltage		Syn	chronized system
	12hrs base tank		AMF function		415/240V		CHINT Cabinet
	24hrs base tank		ATS control cabinet		400/230V		SCHNEIDER Cabinet
	Dual wall base fuel tank		DSE7320		380/220V		DSE8610 Module
	Outside fuel tank		DSE7510		220/127V		COMAQ Module
			GU620A		200/115V	П	DEIF Module

Dimension & Weight Open

Overall Size:	3000×1054×1758
L×W×H (mm)	
Weight (kg)	2460

Soundproof Version

Overall Size:	4200×1400×2150
L×W×H (mm)	
Weight (kg)	4100

Sales Promises

- ◆ FDK provides a full line of brand new and high quality products. Each and every unit is strictly factory tested before shipment.
- Quality warranty is according to our standard conditions: 12 months from BL date or 1000 running hours, whichever comes
- Service and parts are available from FDK or distributors in your location.
- ◆ FDK guarantee use **BRAND NEW & GENUINE MACHINE**.







CHONGQING CUMMINS ENGINE PERFORMANCE CURVE

Engine Model NT855-GA

Data Sheet

Curve No. C-0171A

Date **2006-9-22**

3469 C-0171A

CPL Code


Emission Level


Displacement: 14L [855 in.3] Cylinders: 6 Fuel System: PT

Bore: 140mm [5.50 in.] Speed: 1500 r/min Cfg. Number: D092553DX02

Stroke: 152mm [6.00in.] Aspiration: Turbocharged

Standby Power		Prime Power		Continuo	us Power
kW HP		kW HP		kW	HP
254	340	231	310		





	Output	: Power	Fuel Consumption		Fuel Rate	
	HP	kW	kg/h	L/h	g/kW-h	
Standby100%	340	254	48.5	58.4	191.0	
Prime100%	310	231	44.3	53.4	191.8	
75%	233	173	34.3	41.3	197.8	
50%	155	116	24.4	29.4	211.4	
25%	78	58	14.5	17.5	251.1	
10%	31	23	8.2	9.9	355.0	

All data is based on :

- --Engine Operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer, fan, and optional driven components.
- --Engine operating with fuel corresponding to grade No.2-D per ASTM D975.
- --ISO 3046, Part1, Standard Reference Conditions of : Barometric Pressure:100kPa(29.5in.Hg); Air Temperature: 25°C (77°F); Relative Humidity: 30%.

STAUS FOR CURVES AND DATA:

CHIEF ENGINEER:

TOLERANCE: +/-5%



POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

CONTINUOUS POWER RATING is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

<u>PRIME POWER RATING</u> is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

UNLIMITED TIME RUNNING PRIME POWER

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

Operation At Elevated Temperature And Altitude:

The engine may be operated at:

1800 RPM up to 5000 ft. (1525 m) and 104 $^{\circ}\text{F}$ (40 $^{\circ}\text{C}) without power deration.$

1500 RPM up to 5000 ft. (1525 m) and 104 $^{\circ}\text{F}$ (40 $^{\circ}\text{C}) without power deration.$

For sustained operation above these conditions, derate by 4% per 1,000 ft. (300 m), and 1% per 10 $^{\circ}$ F (2% per 11 $^{\circ}$ C).



Chongqing Cummins Engine Co. Ltd.

Engine Data Sheet

CCEC MODEL: NT855-GA DATA SHEET: C-0171A
NFIGURATION NO.: D092553DX02 PERFORMANCE CURVE: C-0171A
CPL NUMBER: 3469 INSTALLATION DIAGRAM: 4915106
PRIME POWER: 310 HP (231 kW) at 1500 r/min DATE: 2006/9/22

STANDBY POWER: 340 HP (254 kW) at 1500 r/min EMISSION LEVEL:

(2011/1001/1001/1001/1001/1001/1001/1001		
GENERAL ENGINE DATA	26 020 020 020	L 400 10
Type		
Aspiration		
Bore x Stroke - in. ×in. (mm×mm)		(140 × 152) (14)
Displacement - in. ³ (L)		(14)
Firing Order		1
	. 10002	,
Dry Weight	0000	/ 4070 \
Fan to Flywheel Engine - Ib. (kg)		(1270) (1380)
Heat Exchanger Cooled Engine - Ib. (kg)	3040	(1360)
Fan to Flywheel Engine - lb. (kg)	. 2900	(1320)
Heat Exchanger Cooled Engine - Ib. (kg)		(1480)
55A 5 55A	440 5	(4.99)
Moment of Inertia of Rotating Components - With FW1109 flywheel - Ib.·ft. ² (kg·m ²) Center of Gravity from Rear Face of Flywheel Housing - in.(mm)		(704)
Center of Gravity Above Crankshaft Centerline - in.(mm)		(140)
	. 0.0	(140)
ENGINE MOUNTING	4000	(1050)
Maximum Allowable Bending Moment at Rear Face of Block - Ib.·ft. (N·m)	. 1000	(1356)
EXHAUST SYSTEM		
Maximum Allowable Back Pressure - in.Hg (kPa)		(10)
Standard Exhaust Pipe Diameter - in. (mm)	5.0	(127)
AIR INDUCTION SYSTEM		
Maximum Allowable Intake Air Restriction		
With Clean Filter Element - in. H ₂ O (kPa)		(3.74)
With Dirty Filter Element - in. H ₂ O (kPa)		(6.22)
Minimum Dirt Holding Capacity - g/CFM (g/L/s)		(53)
Maximum Allowable Intake Air Temperature ΔT - °F (°C)	30	(17)
COOLING SYSTEM		
Coolant Capacity - Engine Only - U.S. gal (L)	5.5	(20.8)
- With Radiator - U.S. gal (L)		(60.6)
- With Heat Exchanger - U.S. gal (L)		(49.2)
Maximum Coolant Friction Head External to Engine - PSI (kPa)		(41)
Maximum Coolant Pressure(exclusive of Pressure Cap) - PSI (kPa)		(276)
Maximum Static Head of Coolant Above Engine Crank Centerline -ft. (m) Standard Thermostat (Modulating) Range - °F (°C)		(14.0) (82 - 94)
Minimum Allowable Pressure Cap -PSI (kPa)		(48.2)
Maximum Coolant Temperature - °F (°C)		(96)
Maximum Top Tank Temperature - °F (°C)		(100)
Minimum Top Tank Temperature - °F (°C)		(71)
Maximum Allowable Top Tank Temperature for Standby / Prime Power - °F (°C)		
Minimum Recommended Top Tank Temperature - °F (°C)	. 160	(71)
Minimum Coolant Expansion Space - % of System Capacity		
Minimum Coolant Makeup Capacity - U.S. gal (L)		(4.2)
Maximum Raw Water Pressure at Engine Outlet -PSI (kPa)		(103)
Maximum Inlet Restriction at Raw Water Pump - in.Hg (kPa)	10	(34)

Maximum Raw Water Pump Initial Suction Lift- ft. (m)	3.05 2 4	(10) (51) (28)
LUBRICATION SYSTEM		
Oil Pressure @ Idle Speed - PSI (kPa) @ Governed Speed - PSI (kPa) Maximum Allowable Oil Temperature - °F (°C) Oil Pan Capacity - Low / High - U.S. gal. (L) Total System Capacity - U.S. gal. (L)	15 Min 35-50 250 7.5 / 9.5 10.2	(103) Min (241 - 345) (121) (28.4/36.0) (38.6)
Angularity of Oil Pan - Front Down/Front Up/Side to Side	38°/38°/38°	
FUEL SYSTEM		
Type Injection System	iection Cum	mine PT
Maximum Allowable Restriction to Fuel Pump	collon oun	111113 1 1
With Clean Fuel Filter - in.Hg (kPa)	4.0	(13.5)
With Dirty Fuel Filter - in.Hg (kPa)	8.0	(27.1)
Maximum Allowable Head on Injector Return Line	NALAKAI	()
With Check Valve - in Hg (kPa)	6.5	(22.0)
Without Check Valve - in Hg (kPa)	2.5	(8.5)
Minimum Fuel Supply Line Size - in. (mm)	0.625	(16)
Minimum Fuel Return Line Size - in. (mm)	0.5	(13)
Maximum Fuel Pump Supply - U.S.gal/h (L)	61	(232)
Fuel Rail Pressure - PSI (kPa)	166	(1148)
Maximum Fuel Temperature °F (°C)	160	(71)
ELECTRICAL SYSTEM		
Minimum Recommended Battery Capacity (24V)		
Cold Soak (No Load) - CCA	900	
- Minimum Reserved Capacity - CCA	320	
Cold Soak (With Load) - CCA	900	
- Minimum Reserved Capacity - CCA	320	
Maximum Allowable Resistance of Cranking Circuit - ohm	0.002	
Standard Cranking Motor (Heavy Duty, Positive Engagement) - volt	24	
Standard Battery Charging System , Negative Ground - ampere	35	
PERFORMANCE DATA		
Idle Speed - r/min	575 - 650	
Maximum No-Load Governed Speed - r/min	1800	
Maximum over Speed Capability - r/min	2700	
Minimum Crankshaft Rotation for unaided Cold Start - r/min	150	
Minimum Torque for unaided Cold Start - Ib.·ft. (N·m)	375	(509)
Exhaust Sound Pressure at 1m from Exhaust Outlet -1500r/min -dBA	N/A	a; ei

All data is based on :

- --Engine Operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer, fan, and optional driven components.
- -- Engine operating with fuel corresponding to grade No.2-D per ASTM D975.
- --ISO 3046, Part1, Standard Reference Conditions of : Barometric

Pressure:100kPa(29.5in.Hg); Air Temperature: 25°C (77°F); Relative Humidity: 30%.

--This Data Sheet includes both air-cooled (Fan/Radiator) & raw water cooled (Heatexchanger/Raw Water Pump) type engine.

Г	Prime Power		Standby Power	
Γ	50Hz		50Hz	
Governed Engine Speed - r/min	1500		1500	
Gross Engine Power Output - HP (kW)	310	(231)	340	(254)
Torque lb.·ft. (N·m)	1085	(1471)	1192	(1617)
Brake Mean Effective Pressure - PSI (kPa)	191	(1320)	210	(1451)
Piston Speed - ft./min (m/s)	1500	(7.62)	1500	(7.62)
Friction Horsepower - HP (kW)	30	(22)	30	(22)
Intake Air Flow - CFM (L/s)	610	(288)	648	(306)
Engine Water Flow - GPM (L/min.)	79	(5)	79	(5)
Raw Water Flow - GPM (L/s)	54	(3.4)	54	(3.4)
Fuel Consumption - U.S.gal/h (L/h)	14.1	(53)	15.5	(59)
Oil Flow - GPM (L/s)	35	(2.2)	35	(2.2)
Exhaust Gas Temperature (After Turbine) - °F (°C)	859	(459)	877	(469)
Exhaust Gas Flow (After Turbine) - CFM (L/s)	1373	(650)	1458	(690)
Heat Radiation - BTU (kW)	1640	(29)	1810	(32)
Heat Rejection to Coolant - BTU (kW)	9860	(173)	10840	(191)
Heat Rejection to Ambient - BTU (kW)	8220	(144)	9040	(159)

Engine Model: NT855-GA Data Sheet: C-0171A Date: 2006/9/22

CHONGQING CUMMINS ENGINE CO. LTD, CHONGQING, CHINA, 400031