

GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995 Email: info@fdkenergy.com

Web: www.fdkenergy.com


DATA SHEET

DIESEL GENERATOR 352KW

MODEL#FDK-CC440/H2

60HZ/1800RPM

CUMMINS MODEL: NTA855-G3



General Features:

- All qualified generator sets are subjected to a comprehensive performance test which includes 50% load, 70% load, 100% load, 110% load and to check, verify that all control systems, alarm and shut-down protection.
- Equipped with battery charger and 24V high performance maintenance-free lead-acid starting batteries and connecting cables
- Stainless galvanized zinc plates with strong corrosion-proof.
- Vibration isolators between the engine/alternator and base frame.
- Equipped with industrial silencer and flexible exhaust hose.
- Designed to comply with ISO8528/GB2820.
- Powered by Cummins engine and coupled with Stamford alternator.
- Water jacket preheater, oil heater and double air cleaner, etc. are available.

FDK Diesel Generator Set Data

Genset Model	FDK-CC440/H2
Prime Power	319KW/400KVA
Standby Power	350KW/440KVA
Output Frequency / Rated speed	60Hz/1800rpm
Rated Voltage	230V/400V

Engine Make	Cummins
Engine Model	NTA855-G3
Alternator model	Stamford HCI444F
Control System	DSE7320
Phase	Three

- (1) **Prime power**: The rating is available for an unlimited of annual operating hours in variable load applications, in accordance with ISO8528-1.A 10% overload is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046-1.
- (2) **Standby power**: The rating is applicable for supplying emergency power in variable load applications for up to 200 hours per year in accordance with ISO8528-1. Overload is not allowed.
- (3) Rated voltage: available with customer requirement.

Engine Specifications (DETAILED in APPENDIX)

Engine Model	NTA855-G3
Engine Manufacturer	Cummins
	(CCEC CHINA)
Cylinder quantity	6
Cylinder Arrangement	In-line
Cycle	4

Aspiration	Turbo-charged
Bore x Stroke (mm x mm)	140×152
Displacement	14L
Compression Ratio	14.0:1
Prime power / Speed (KW/RPM)	358/1800
Standby power/ Speed (KW/RPM)	399/1800







Tel: 86-13710087995

with

		Web: www.fdkenergy.com Em	Email: info@fdkenergy.com	
Type Injection System	Direct injection	Fuel Consumption at 100% load	87 at 1800rpm	
	Cummins PT	(L/HOUR)		
Piston Speed	9.1m/s	Starter motor	24V	
Friction Energy Output	35kw	Low idle	575-675rpm	
Total Lubrication System Capacity (L)	38.6	Coolant Capacity (L)	20.8L	

Alternator Specifications

Alternator model	HCI444F	Number of phase	3
Alternator manufacturer	STAMFORD	Rated voltage	480V (Available
Exciter type	Single bearing, Brushless,		custom requirements)
	Self-excited	Power factor	0.8
Rated output prime power	500KVA	Voltage regulation NL-FL	≤±1%
Rated speed	1800 rpm	Insulation grade	Н
Rated frequency	60Hz	Protection grade	IP23

Alternator option: Leroy Somer, MECC, Marathon, Engga, Faraday

Control System DSE7320 (DETAILED in INSTRUCTION)

DSE7320 is an advanced control module based on micro-processor, containing all necessary functions for protection of the genset and the breaker control. It can monitor the mains supply, breaker control and automatically start the engine when the mains are abnormal. Accurately measure various operational parameters and display all values and alarms information on the LCD. In addition, the control module can automatically shut down the engine and indicate the engine failure.

FEATURES

- Microprocessor control, with high stability and credibility.
- Monitoring and measuring operational parameters of the mains supply and genset.
- Indicating operation status, fault conditions, all parameters and alarms.
- Multiple protections; multiple parameters display, like pressure, temp. etc.
- Manual, automatic and remote work mode selectable.
- Real time clock for time and date display, overall runtime display, 250 log entries.
- Overall power output display.
- Integral speed/frequency detecting, telling status of start, rated operation, overspeed etc.
- Communication with PC via RS485 OR RS232 interface, using MODBUS protocol.

Soundproof Enclosure Specification

FDK silent generator is designed by professional acoustic engineers based on years of experience. Now we can make the noise of the generator less than 80-85dB(A) at 1m, or 70-75dB(A) at 7m, 60-65dB(A) at 15m.

FEATURES

- Multi-way air intake and exhaust guarantee the power performance of the generator.
- Large-scale impedance combined type silencer effectively reduce noise of the generator.
- Internal high performance rubber damper and flexible materials reduce vibration.
- Base mounted fuel tank supports the generator running for 8 hours.







GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-13710087995

Web: www.fdkenergy.com Email: info@fdkenergy.com

Optional

Gen	erator set	Alte	rnator	Low environment Temp		ATS	
	Open generator set		Stamford		Water heater		CHINT
	Silent generator set		Marathon		Oil heater		SCHNEIDER
	Trailer generator set		Mecc Alte		Battery heater		ABB
	ABB MCCB circuit breaker		Leroy Somer				
			Farady				
			Engga				
Fue	Fuel system Control system		trol system	Volta	age	Syn	chronized system
	12hrs base tank		AMF function		415/240V		CHINT Cabinet
	24hrs base tank		ATS control cabinet		400/230V		SCHNEIDER Cabinet
	Dual wall base fuel tank		DSE7320		380/220V		DSE8610 Module
	Outside fuel tank		DSE7510		220/127V		COMAQ Module
			GU620A		200/115V		DEIF Module

Dimension & Weight Open

Overall Size:	3050×1060×1900
L×W×H (mm)	
Weight (kg)	2600

Soundproof Version

Overall Size:	4800×1350×2350
L×W×H (mm)	
Weight (kg)	3400

Sales Promises

- ♦ FDK provides a full line of brand new and high quality products. Each and every unit is strictly factory tested before shipment.
- Quality warranty is according to our standard conditions: 12 months from BL date or 1000 running hours, whichever comes
- Service and parts are available from FDK or distributors in your location.
- ◆ FDK guarantee use BRAND NEW & GENUINE MACHINE.





Displacement: 14.0 litre (855 in³)

CHONGQING CUMMINS ENGINE COMPANY Ltd.

ENGINE PERFORMANCE CURVE

Basic Engine Model: NTA855-G3

Curve Number: C-4495

Page No. 1

Engine Critical Parts List: **CPL: 1436**

Stroke: 152 mm (6.0 in.)

Date: 06Jan2004

No. of Cylinders: 6 Aspiration: Turbocharged and Aftercooled

Bore: 140 mm (5.5 in.)

Engine Speed	Standby Power		Prime Power		Continuo	us Power
RPM	kWm	ВНР	kWm	ВНР	kWm	ВНР
1500						
1800	399	535	358	480	280	375


Engine Performance Data @ 1500 RPM

Not Available at 1500 RPM

Not Available at 1500 RPM

Engine Performance Data @ 1800 RPM

b/ litre/ hour	U.S. Gal/ hour					
336 96						
336 96	0=0					
1 00	25.3					
PRIME POWER						
339 87	22.9					
345 66	17.5					
384 47	12.3					
120 27	7.1					
CONTINUOUS POWER						
344 69	18.2					
1	345 66 384 47 420 27					



CONVERSIONS:

(Litres = U.S. Gal x 3.785)

(Engine kWm = BHP x 0.746)

 $(U.S. Gal = Litres \times 0.2642)$

(Engine BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No.2 diesel or a fuel corresponding to AŠTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

CONTINUOUS POWER RATING is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

PRIME POWER RATING is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

UNLIMITED TIME RUNNING PRIME POWER

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

Operation At Elevated Temperature And Altitude:

The engine may be operated at:

1800 RPM up to 5,000 ft. (1525 m) and 104 $^{\rm o}{\rm F}$ (40 $^{\rm o}{\rm C})$ without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per 10 $^{\rm o}$ F (2% per 11 $^{\rm o}$ C).

Chongqing Cummins Engine Company Ltd.

Engine Data Sheet

DATA SHEET: DS-4495 ENGINE MODEL: NTA855-G3 DATE: 06Jan2004
PERFORMANCE CURVE: C-4495 **CONFIGURATION NUMBER:** D093580DX02

INSTALLATION DIAGRAM
• Fan to Flywheel :

<u>CPL NUMBER</u>
• Engine Critical Parts List : 1436

· · ·				6-Cylinder Diesel
•	—in x		5.5 x 6.0 (140 x	and Aftercooled
		`	855 (14.0)	102)
•		, ,	14.0 : 1	
Dry Weight				
	I Engine	— lb (ka)	2900	(1315)
•	r Cooled Engine	` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` `	3130	(1420)
Wet Weight	1 Ooolea Erigine	ib (Ng)	3130	(1420)
	l Engine	— lb (ka)	3018	(1369)
•	r Cooled Engine		3308	(1501)
Moment of Inertia o	f Rotating Components			
 with FW 1109 Fly 	wheel lb _n	$_{1} \bullet \text{ ft}^2 \text{ (kg} \bullet \text{m}^2\text{)}$	118.5	(4.99)
	wheel — Ib _n		180.3	(7.60)
Center of Gravity fro	om Rear Face of Flywheel Housing	— in (mm)	27.7	(704)
Center of Gravity Al	pove Crankshaft Centerline	— in (mm)	5.5	(140)
Maximum Static Lo	ading at Rear Main Bearing	— lb (kg)		N.A.
ENGINE MOUNT	ING			
Maximum Bending	Moment at Rear Face of Block –	- lb • ft (N • m)	1000	(1356)
EXHAUST SYST				
Maximum Back Pre	ssure— i	n Hg (mm Hg)	3	(76)
AIR INDUCTION Maximum Intake Ai				
,	ement— in H	_ \ _ /	25	(635)
	Air Cleaner and Clean Filter Element — in H		10	(254)
• with Heavy Duty A	Air Cleaner and Clean Filter Element — in H	₂ O (mm H ₂ O)	15	(381)
COOLING SYST	EM			
Coolant Capacity	— Engine Only	– US gal (liter)	5.5	(20.8)
	— with HX 1134 Heat Exchanger –	– US gal (liter)	13.0	(49.2)
Maximum Coolant F	Friction Head External to Engine — 1800 rpm	. ,	7	(48)
	— 1500 rpm		6	(41)
	ad of Coolant Above Engine Crank Centerline	, ,	60	(18.3)
	at (Modulating) Range		180 - 200	(82 - 93)
	Cap		10	(69)
	Temperature for Standby / Prime Power		220 / 212	(104 / 100)
	er Flow @ 90°F to HX 1134 Heat Exchanger — US g		54	(204)
Maximum Raw Wat	er Inlet Pressure at HX 1134 Heat Exchanger	— psi (kPa)	50	(345)
LUBRICATION S				
Oil Pressure @ Idl	e Speed	— psi (kPa)	15	(103)
@ G	overned Speed	— psi (kPa)	35 - 45	(241 - 310)
	erature		250	(121)
· · ·	P 1396 Oil Pan : High - Low	• , ,	9.5 - 7.5	(36.0 - 28.4)
	city (Including Combo Filter)		10.2	(38.6)
Angularity of OP 13				45°
	— Front Up			45°
	— Side to Side			45°

FUEL SYSTEM

Type Injection System	Direct Injection	Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter — in Hg (mm Hg)	4.0	(102)
— with Dirty Fuel Filter— in Hg (mm Hg)	8.0	(203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.0	(152)
Maximum Fuel Flow to Injection Pump	107	(405)
ELECTRICAL SYSTEM		
Cranking Motor (Heavy Duty, Positive Engagement)	24	
Battery Charging System, Negative Ground — ampere	35	
Maximum Allowable Resistance of Cranking Circuit — ohm	0.002	
Minimum Recommended Battery Capacity		
• Cold Soak @ 50 °F (10 °C) and Above — 0°F CCA	600	
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	640	
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C)	900	
COLD START CAPABILITY		
Minimum Ambient Temperature for Aided (with Coolant Heater) Cold Start within 10 seconds — °F (°C)	50	(10)
Minimum Ambient Temperature for Unaided Cold Start	20	(-7)

PERFORMANCE DATA

All data is based on:

- Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components.
- Engine operating with fuel corresponding to grade No. 2-D per ASTM D975.
- ISO 3046. Part 1. Standard Reference Conditions of:

Barometric Pressure : 100 kPa (29.53 in Hg) Air Temperature : 25 °C (77 °F)

: 110 m (361 ft) Relative Humidity : 30%

+/- 0.25 Estimated Free Field Sound Pressure Level of a Typical Generator Set; N.A. N.A.

Governed Engine Speedrpm
Engine Idle Speed — rpm
Gross Engine Power Output BHP (kW _m)
Brake Mean Effective Pressure— psi (kPa)
Piston Speed—ft / min (m / s)
Friction Horsepower — HP (kW _m)
Engine Water Flow at Stated Friction Head External to Engine:
• 2 psi Friction Head (estimated) — US gpm (liter / s)
 Maximum Friction Head (estimated)— US gpm (liter / s)

per (in a)
Piston Speed — ft / min (m / s)
Friction Horsepower — HP (kW _m)
Engine Water Flow at Stated Friction Head External to Engine:
• 2 psi Friction Head (estimated)
Maximum Friction Head (estimated) — US gpm (liter / s)

Engine Data with Dry Type Exhaust Manifold

Intake Air Flow	cfm (liter / s)
Exhaust Gas Temperature	°F (°C)
Exhaust Gas Flow	cfm (liter / s)
Air to Fuel Ratio	— air : fuel
Radiated Heat to Ambient	BTU / min (kW _m)
Heat Rejection to Coolant	BTU / min (kW _m)
Heat Rejection to Exhaust	BTU / min (kW _m)

STANDBY POWER 60 hz 50 hz		6	PRIME POWER 60 hz 50 hz		
	800 5 - 675 (399) (1896) (9.1) (35) (8.2) (7.3)	Not Available at 1500 RPM (50 hz)		800 5 - 675 (358) (1703) (9.1) (35) (8.2) (7.3)	Not Available at 1500 RPM (50 hz)
1150 980 3190 27.3 3285 13375 15420	(543) (527) (1506) 3:1 (58) (235) (271)		1010 970 2785 26. 2975 12000 14245	(477) (521) (1315) 7:1 (52) (211) (250)	

N.A. - Data is Not Available

N/A - Not Applicable to this Engine

TBD - To Be Determined

ENGINE MODEL: NTA855-G3

DATA SHEET: DS-4495 **DATE**: 06Jan2004 **CURVE NO.:** C-4495