

#### **GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD** SHENZHEN FUDIANKANG DIESEL GENSET CO., LTD

Tel:86-13729889887 Fax:86-20-84550026 Email: info@fdkenergy.com

Web: www.fdkenergy.com

# **DATA SHEET**

**DIESEL GENERATOR 880KW** MODEL#FDK-CG1100/H1 50HZ/1500RPM **CUMMINS MODEL: KTA38-G5** 



#### **General Features:**

- All qualified generator sets are subjected to a comprehensive performance test which includes 50% load, 70% load, 100% load, 110% load and to check, verify that all control systems, alarm and shut-down protection.
- Equipped with battery charger and 24V high performance maintenance-free lead-acid starting batteries and connecting
- Stainless galvanized zinc plates with strong corrosion-proof.
- Vibration isolators between the engine/alternator and base frame.
- Equipped with industrial silencer and flexible exhaust hose.
- Designed to comply with ISO8528/GB2820.
- Powered by Cummins engine and coupled with Stamford alternator.
- Water jacket preheater, oil heater and double air cleaner, etc. are available.

#### **FDK Diesel Generator Set Data**

Genset Model	FDK-CG880/H1
Prime Power	800KW/1000KVA
Standby Power	880KW/1100KVA
Output Frequency / Rated speed	50Hz/1500rpm
Rated Voltage	230V/400V

Engine Make	Cummins ONAN
Engine Model	KTA38-G5
Alternator model	Stamford HCl634J
Control System	DSE7320
Phase	Three

- (1) Prime power: The rating is available for an unlimited of annual operating hours in variable load applications, in accordance with ISO8528-1.A 10% overload is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046-1.
- (2) Standby power: The rating is applicable for supplying emergency power in variable load applications for up to 200 hours per year in accordance with ISO8528-1. Overload is not allowed.
- (3) Rated voltage: available with customer requirement.

#### Engine Specifications (DETAILED in APPENDIX)

Engine Model	KTA38-G5		
Engine Manufacturer	Cummins		
	ORIGINAL INDIA		
Cylinder quantity	12		
Cylinder Arrangement	60° Vee		
Cycle	4		

Aspiration	Turbo-charged
Bore x Stroke (mm x mm)	159×159
Displacement	37.8L
Compression Ratio	13.9:1
Prime power / Speed (KW/RPM)	880kw/1500
Standby power/ Speed (KW/RPM)	970kw/1500







# GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENSET CO., LTD

Tel:86-13729889887 Fax:86-20-84550026

		Web: www.fdkenergy.com E	mail: info@fdkenergy.com	
Type Injection System	Cummins PT	Cummins PT Fuel Consumption at 100% load		
	Direct Injection	(g/KWh)		
Piston Speed	7.9m/s	Starter motor	DC24V	
Friction Energy Output	86kw	Low idle	725-775pm	
Total Lubrication System Capacity	135L	Coolant Capacity (L)	129	

#### **Alternator Specifications**

Alternator model	HCI634J	Number of phase	3
Alternator manufacturer	STAMFORD	ORD Rated voltage	
Exciter type	Single bearing, Brushless,		custom requirements)
	Self-excited	Power factor	0.8
Rated output prime power	1000KVA	Voltage regulation NL-FL	≤±1%
Rated speed	1500 rpm	Insulation grade	Н
Rated frequency	50Hz	Protection grade	IP23
	•		

Alternator option: Leroy Somer, MECC, Marathon, Engga, Faraday

#### Control System DSE7320 (DETAILED in INSTRUCTION)

DSE7320 is an advanced control module based on micro-processor, containing all necessary functions for protection of the genset and the breaker control. It can monitor the mains supply, breaker control and automatically start the engine when the mains are abnormal. Accurately measure various operational parameters and display all values and alarms information on the LCD. In addition, the control module can automatically shut down the engine and indicate the engine failure.

#### **FEATURES**

- Microprocessor control, with high stability and credibility.
- Monitoring and measuring operational parameters of the mains supply and genset.
- Indicating operation status, fault conditions, all parameters and alarms.
- Multiple protections; multiple parameters display, like pressure, temp. etc.
- Manual, automatic and remote work mode selectable.
- Real time clock for time and date display, overall runtime display, 250 log entries.
- Overall power output display.
- Integral speed/frequency detecting, telling status of start, rated operation, overspeed etc.
- Communication with PC via RS485 OR RS232 interface, using MODBUS protocol.

#### **Soundproof Enclosure Specification**

FDK silent generator is designed by professional acoustic engineers based on years of experience. Now we can make the noise of the generator less than 80-85dB(A) at 1m, or 70-75dB(A) at 7m, 60-65dB(A) at 15m.

#### **FEATURES**

- Multi-way air intake and exhaust guarantee the power performance of the generator.
- Large-scale impedance combined type silencer effectively reduce noise of the generator.
- Internal high performance rubber damper and flexible materials reduce vibration.
- Base mounted fuel tank supports the generator running for 8 hours.







# GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENSET CO., LTD

Tel:86-13729889887 Fax:86-20-84550026

Web: www.fdkenergy.com Email: info@fdkenergy.com

#### **Optional**

Ger	erator set	Alternator		Low environment Temp		ATS	
	Open generator set		Stamford		Water heater		CHINT
	Silent generator set		Marathon		Oil heater		SCHNEIDER
	Trailer generator set		Mecc Alte		Battery heater		ABB
	ABB MCCB circuit breaker		Leroy Somer				
			Farady				
			Engga				
Fue	l system	Control system		Voltage		Synchronized system	
	12hrs base tank		AMF function		415/240V		CHINT Cabinet
	24hrs base tank		ATS control cabinet		400/230V		SCHNEIDER Cabinet
	Dual wall base fuel tank		DSE7320		380/220V		DSE8610 Module
	Outside fuel tank		□ DSE7510		220/127V		COMAQ Module
			GU620A		200/115V		DEIF Module

# Dimension & Weight Open

Overall Size:	4200×1820×2350
L×W×H (mm)	
Weight (kg)	7800

#### **Soundproof Version**

Overall Size:	6000×2300×2550
L×W×H (mm)	
Weight (kg)	9800

#### **Sales Promises**

- ◆ FDK provides a full line of brand new and high quality products. Each and every unit is strictly factory tested before shipment.
- Quality warranty is according to our standard conditions: 12 months from BL date or 1000 running hours, whichever comes
- ♦ Service and parts are available from FDK or distributors in your location.
- ◆ FDK guarantee use **BRAND NEW & GENUINE MACHINE**.







#### **CUMMINS ENGINE COMPANY, INC**

Columbus, Indiana 47201

#### **ENGINE PERFORMANCE CURVE**

Basic Engine Model: **KTA38-G5** 

Curve Number: FR-6140

Date:

Page No.

Engine Critical Parts List: **CPL: 1543** 

02Sep98


Displacement: 37.8 litre (2300 in<sup>3</sup>) Bore: 159 mm (6.25 in.) Stroke: 159 mm (6.25 in.)

No. of Cylinders: 12 Aspiration: Turbocharged and Aftercooled

Engine Speed	Standby Power		Prime Power		Continuous Power	
RPM	kWm	ВНР	kWm	ВНР	kWm	ВНР
1500	970	1300	880	1180	656	880
1800						

## **Engine Performance Data @ 1500 RPM**

OUTPUT POWER			FUEL CONSUMPTION			
%	kWm	ВНР	kg/ kWm∙h	lb/ BHP∙h	litre/ hour	U.S. Gal/ hour
STAN	DBY PO	WER				
100	970	1300	0.200	0.329	228	60.3
PRIME POWER						
100	880	1180	0.202	0.332	209	55.1
75	660	885	0.207	0.341	161	42.5
50	440	590	0.218	0.360	113	29.9
25	220	295	0.251	0.416	65	17.3
CONTINUOUS POWER						
100	656	880	0.204	0.336	158	41.7



## **Engine Performance Data @ 1800 RPM**

Not Available at 1800 RPM

Not Available at 1800 RPM

**CONVERSIONS:** 

TECHNICAL DATA DEPT.

(Litres = U.S. Gal x 3.785)

 $(kWm = BHP \times 0.746)$ 

 $(U.S. Gal = Litres \times 0.2642)$ 

(BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

**CHIEF ENGINEER CERTIFIED WITHIN 5%** 

# POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

CONTINUOUS POWER RATING is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating.

PRIME POWER RATING is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

#### **UNLIMITED TIME RUNNING PRIME POWER**

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

#### **LIMITED TIME RUNNING PRIME POWER**

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

#### Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

#### **Operation At Elevated Temperature And Altitude:**

The engine may be operated at:

1500 RPM up to 5,000 ft. (1525 m) and 104 $^{\rm o}$  F (40 $^{\rm o}$  C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per 10° F (2% per 11° C).

# **Cummins Engine Company, Inc.**

### **Engine Data Sheet**

DATA SHEET: DS-4891-A
DATE: 02Sep98
PERFORMANCE CURVE: FR-6140 ENGINE MODEL: KTA38-G5 **CONFIGURATION NUMBER:** D233031DX02

**INSTALLATION DIAGRAM** 

**CPL NUMBER** 

• Fan to Flywheel : 3383897 • Engine Critical Parts List : 1543

•	Heat	Exc	har	nger	Coo	led	:
---	------	-----	-----	------	-----	-----	---

Type			e; 12-Cylinder Die	
Aspiration  Bore x Stroke		Turbocharged		
Displacement	` _ ,	6.25 x 6.25 (159 x 159)		
	, ,	2300 (37.8)		
Compression Ratio		13.9 : 1		
Dry Weight				
Fan to Flywheel Engine	— lb (kg)	9482	(4300)	
Heat Exchanger Cooled Engine	— lb (kg)	9923	(4500)	
Wet Weight				
Fan to Flywheel Engine	— lb (kg)	10002	(4536)	
Heat Exchanger Cooled Engine	— lb (kg)	10602	(4808)	
Moment of Inertia of Rotating Components				
with FW 6001 Flywheel	— $lb_m \cdot ft^2 (kg \cdot m^2)$	248	(10.4)	
• with FW 6011 Flywheel		493	(20.8)	
Center of Gravity from Rear Face of Flywheel Housing (FH 6024)		38.6	(980)	
Center of Gravity Above Crankshaft Centerline		11.0	(279)	
Maximum Static Loading at Rear Main Bearing	` ,	2000	(908)	
	io (Ng)	2000	(000)	
NGINE MOUNTING  Mayimum Rending Memort at Poor Face of Plack	llo a 64 /N1 =\	4500	(64.00)	
Maximum Bending Moment at Rear Face of Block	— ID • It (IN • III)	4500	(6100)	
XHAUST SYSTEM				
Maximum Back Pressure	— in Hg (mm Hg)	3	(76)	
IR INDUCTION SYSTEM				
Maximum Intake Air Restriction				
• with Dirty Filter Element	— in H <sub>2</sub> O (mm H <sub>2</sub> O)	25	(635)	
with Normal Duty Air Cleaner and Clean Filter Element		10	(254)	
with Heavy Duty Air Cleaner and Clean Filter Element		15	(381)	
	2= (2=)		(== 1)	
OOLING SYSTEM	110 1 (1:4)	20.7	(404)	
Coolant Capacity — Engine Only		32.7	(124)	
— with HX 6076 Heat Exchanger	— US gal (liter)	52.7	(199)	
Maximum Coolant Friction Head External to Engine — 1800 rpm		N/A	N/A	
— 1500 rpm		7	(48)	
Maximum Static Head of Coolant Above Engine Crank Centerline	— ft (m)	60	(18.3)	
Standard Thermostat (Modulating) Range	— °F (°C)	180 - 200	(82 - 93)	
Minimum Pressure Cap	— psi (kPa)	10	(69)	
Maximum Top Tank Temperature for Standby / Prime Power		220 / 212	(104 / 100)	
Minimum Raw Water Flow @ 90°F to HX 6076 Heat Exchanger	— US gpm (liter / min)	108	(409)	
Maximum Raw Water Inlet Pressure at HX 6076 Heat Exchanger		50	(345)	
UBRICATION SYSTEM				
Oil Pressure @ Idle Speed	— psi (kPa)	20	(138)	
@ Governed Speed		45 - 65	(310 - 448)	
Maximum Oil Temperature	· · · · · · · · · · · · · · · · · · ·	250	(121)	
Oil Capacity with OP 6023 Oil Pan : High - Low		30 - 23	(114 - 87)	
Total System Capacity (Including Bypass Filter)		35.7	(135)	
Angularity of OP 6023 Oil Pan — Front Down		33.1	30°	
			30°	
— Front Up				
— Side to Side	•••••		30°	

#### **FUEL SYSTEM**

I OLL OTOTLIN		
Type Injection System	Direct Injection	Cummins PT
Maximum Restriction at PT Fuel Injection Pump — with Clean Fuel Filter	4.0	(102)
— with Dirty Fuel Filter — in Hg (mm Hg)	8.0	(203)
Maximum Allowable Head on Injector Return Line (Consisting of Friction Head and Static Head)	6.5	(165)
Maximum Fuel Flow to Injection Pump	113	(428)
ELECTRICAL SYSTEM		
Cranking Motor (Heavy Duty, Positive Engagement)	24	
Battery Charging System, Negative Ground — ampere	35	
Maximum Allowable Resistance of Cranking Circuit	0.002	
Minimum Recommended Battery Capacity		
• Cold Soak @ 50 °F (10 °C) and Above — 0°F CCA	1200	
• Cold Soak @ 32 °F to 50 °F (0 °C to 10 °C)	1280	
• Cold Soak @ 0 °F to 32 °F (-18 °C to 0 °C)	1800	
COLD START CAPABILITY		
Minimum Ambient Temperature for Aided (with Coolant Heater) Cold Start within 10 seconds	50	(10)
Minimum Ambient Temperature for Unaided Cold Start	45	`(7)

PERFORMANCE DATA All data is based on:

- Engine operating with fuel system, water pump, lubricating oil pump, air cleaner and exhaust silencer; not included are battery charging alternator, fan, and optional driven components.
- Engine operating with fuel corresponding to grade No. 2-D per ASTM D975.
- ISO 3046, Part 1, Standard Reference Conditions of:

Barometric Pressure : 100 kPa (29.53 in Hg) Air Temperature : 25 °C (77 °F) : 110 m (361 ft) Relative Humidity : 30%

+/- 0.25 Estimated Free Field Sound Pressure Level of a Typical Generator Set; N.A.

N.A.

#### **Engine Data with Dry Type Exhaust Manifold**

Intake Air Flow	
Exhaust Gas Temperature	
Exhaust Gas Flow	
Air to Fuel Ratio	— air : fuel
Radiated Heat to Ambient	BTU / min (kW <sub>m</sub> )
Heat Rejection to Coolant	BTU / min (kW <sub>m</sub> )
Heat Rejection to Exhaust	BTU / min (kW <sub>m</sub> )

<u>STA</u>	NDBY	) hz	PRIME	POWER	
60 hz	50		60 hz	50 hz	
Not Applicable for 60 Hz Operation	_	(1213) (513) (594) (590)	Not Applicable for 60 Hz Operation	725 1180 271 1562 115 310 280 2415 930 6465	(19.6) (17.7) (1140) (499) (3051) 5.1 : 1 (125) (539)

N.A. - Data is Not Available N/A - Not Applicable to this Engine

TBD - To Be Determined

**ENGINE MODEL: KTA38-G5** DATA SHEET: DS-4891-A

DATE: 02Sep98 **CURVE NO.:** FR-6140