

GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-1371008799

Web: www.fdkenergy.com Email: info@fdkenergy.com

DATA SHEET

DIESEL GENERATOR 500KW *MODEL#FDK-CG625/H2* 60HZ/1800RPM CUMMINS MODEL: KTA19-G4



General Features:

- All qualified generator sets are subjected to a comprehensive performance test which includes 50% load, 70% load, 100% load, 110% load and to check, verify that all control systems, alarm and shut-down protection.
- Equipped with battery charger and 24V high performance maintenance-free lead-acid starting batteries and connecting cables.
- Stainless galvanized zinc plates with strong corrosion-proof.
- Vibration isolators between the engine/alternator and base frame.
- Equipped with industrial silencer and flexible exhaust hose.
- Designed to comply with ISO8528/GB2820.
- Powered by Cummins engine and coupled with Stamford alternator.
- Water jacket preheater, oil heater and double air cleaner, etc. are available.

Genset Model	FDK-CG625/H2	Engine Make	Cummins Original	
Prime Power	450KW/560KVA	Engine Model	KTA19-G4	
Standby Power	500KW/625KVA	Alternator model	Stamford HCI544D	
Output Frequency / Rated speed	60Hz/1800rpm	Control System	DSE7320	
Rated Voltage	277V/480V	Phase	Three	

FDK Diesel Generator Set Data

(1) **Prime power**: The rating is available for an unlimited of annual operating hours in variable load applications, in accordance with ISO8528-1.A 10% overload is available for a period of 1 hour within 12-hour period of operation, in accordance with ISO 3046-1.

(2) **Standby power**: The rating is applicable for supplying emergency power in variable load applications for up to 200 hours per year in accordance with ISO8528-1. Overload is not allowed.

(3) Rated voltage: available with customer requirement.

Engine Specifications (DETAILED in APPENDIX)

Engine Model	KTA19-G4	Aspiration	Turbo-charged	
Engine Manufacturer	Cummins (Onan	Bore x Stroke (mm x mm)	159×159	
	USA)	Displacement	18.9L	
Cylinder quantity	6	Compression Ratio	13.9:1	
Cylinder Arrangement	In-line	Prime power / Speed (KW/RPM)	563/1800	
Cycle	4	Standby power/ Speed (KW/RPM)	507/1800	





08 FDK reserves the right to change the specifications and designs without noice.



GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-1371008799 Email: info@fdkenergy.com

Type Injection System	Direct Injection
	Cummins PT
Piston Speed	9.5 m/s
Friction Energy Output	63 kw
Total Lubrication System Capacity (L)	50

Web: www.fd	kene	rgy.com	Ema	ail: info@fdkenergy.cor	
Fuel Consumption	at	100%	load	205 at 1800rpm	
(g/KWh)	Wh)				
Starter motor		24V			
Low idle	675-775rpm				
Coolant Capacity (L)		30			

Alternator Specifications

Alternator model	HCI544D	Number of phase	3
Alternator manufacturer	STAMFORD	Rated voltage	480V (Available with
Exciter type	Single bearing, Brushless,		custom requirements)
	Self-excited	Power factor	0.8
Rated output prime power	644KVA	Voltage regulation NL-FL	≤±1%
Rated speed	1800 rpm	Insulation grade	н
Rated frequency	60Hz	Protection grade	IP23

Alternator option: Leroy Somer, MECC, Marathon, Engga, Faraday

Control System DSE7320 (DETAILED in INSTRUCTION)

DSE7320 is an advanced control module based on micro-processor, containing all necessary functions for protection of the genset and the breaker control. It can monitor the mains supply, breaker control and automatically start the engine when the mains are abnormal. Accurately measure various operational parameters and display all values and alarms information on the LCD. In addition, the control module can automatically shut down the engine and indicate the engine failure.

FEATURES

- ٠ Microprocessor control, with high stability and credibility.
- ٠ Monitoring and measuring operational parameters of the mains supply and genset.
- Indicating operation status, fault conditions, all parameters and alarms.
- Multiple protections; multiple parameters display, like pressure, temp. etc.
- Manual, automatic and remote work mode selectable.
- Real time clock for time and date display, overall runtime display, 250 log entries.
- Overall power output display.
- Integral speed/frequency detecting, telling status of start, rated operation, overspeed etc.
- Communication with PC via RS485 OR RS232 interface, using MODBUS protocol. ٠

Soundproof Enclosure Specification

FDK silent generator is designed by professional acoustic engineers based on years of experience. Now we can make the noise of the generator less than 80-85dB(A) at 1m, or 70-75dB(A) at 7m, 60-65dB(A) at 15m.

FEATURES

- ٠ Multi-way air intake and exhaust guarantee the power performance of the generator.
- Large-scale impedance combined type silencer effectively reduce noise of the generator.
- Internal high performance rubber damper and flexible materials reduce vibration.
- Base mounted fuel tank supports the generator running for 8 hours. ٠





ISO9001:2008 FDK reserves the right to change the specifications and designs without noice.



GUANGDONG FUDIANKANG DIESEL GENSET CO., LTD SHENZHEN FUDIANKANG DIESEL GENESET CO., LTD

Tel: 86-1371008799

Web: www.fdkenergy.com Email: info@fdkenergy.com

Ор	tional			_			
Generator set		Alternator		Low environment Temp		ATS	
	Open generator set		Stamford		Water heater		CHINT
	Silent generator set		Marathon		Oil heater		SCHNEIDER
	Trailer generator set		Mecc Alte		Battery heater		ABB
	ABB MCCB circuit breaker	□ Leroy Somer					
			Farady				
			Engga				
Fue	system	Control system		Voltage		Synchronized system	
	12hrs base tank		AMF function		415/240V		CHINT Cabinet
	24hrs base tank		□ ATS control cabinet		400/230V		SCHNEIDER Cabinet
	Dual wall base fuel tank		DSE7320		380/220V		DSE8610 Module
	Outside fuel tank		DSE7510		220/127V		COMAQ Module
			GU620A		200/115V		DEIF Module

Dimension & Weight Open

Soundproof Version

Overall Size:	3300×1620×1950
L×W×H (mm)	
Weight (kg)	4900

Overall Size:	4600×1630×2515
L×W×H (mm)	
Weight (kg)	5340

Sales Promises


- FDK provides a full line of brand new and high quality products. Each and every unit is strictly factory tested before shipment.
- Quality warranty is according to our standard conditions: 12 months from BL date or 1000 running hours, whichever comes first.
- Service and parts are available from FDK or distributors in your location.
- ◆ FDK guarantee use **BRAND NEW & GENUINE MACHINE**.



cummins	CUMMINS ENGINE COM	PANY, INC	Basic Engine Model: KTA19-G4	Curve Number: FR-4212	Page No.		
cum	Columbus, Indiana 47	-	Engine Critical Parts List:	Date: 09Dec98			
Displacement : 18.9 litre (1150 in ³) Bore :		Bore : 15	59 mm (6.25 in.) Stroke : 159 mm				
No. of Cylinders : 6 Aspiration			ation : Turbocharged and Aftercooled				

Engine Speed	ine Speed Standby Power Prime Power				Continuous Power	
RPM	kWm BHP		BHP kWm BHP		kWm	BHP
1500	504 675		448	600	355	475
1800	563	755	507	680	429	575

Engine Performance Data @ 1500 RPM



Engine Performance Data @ 1800 RPM

OUTP	PUT PO	WER	F	JEL CON	SUMPT	ON	U.S. Gallons/hour 40.0		
%	kWm	BHP	kg/ kWm∙h	lb/ BHP∙h	litre/ hour	U.S. Gal/ hour	35.0 1800 RPM		
STANDBY POWER							30.0		
100	563	755	0.206	0.338	136	35.9	25.0		
PRIME	POWE	R				•	20.0		
100	507	680	0.205	0.337	122	32.3	15.0		
75	380	510	0.210	0.346	94	24.8	10.0	-	
50	254	340	0.218	0.355	65	17.0			
25	127	170	0.241	0.401	36	9.6	5.0		
CONTI	INUOUS	POWE	R			•		لت. POD	
100	429	575	0.207	0.340	104	27.5	0 100 200 300 400 500 600 700 Gross Engine Power Output - BHP	800	

CONVERSIONS: (Lit

(Litres = U.S. Gal x 3.785)

(Engine kWm = BHP x 0.746)

.746) (U.S. Gal = Litres x 0.2642)

(Engine BHP = Engine kWm x 1.34)

Data shown above represent gross engine performance capabilities obtained and corrected in accordance with ISO-3046 conditions of 100 kPa (29.53 in Hg) barometric pressure [110 m (361 ft) altitude], 25 °C (77 °F) air inlet temperature, and relative humidity of 30% with No. 2 diesel or a fuel corresponding to ASTM D2. See reverse side for application rating guidelines.

The fuel consumption data is based on No. 2 diesel fuel weight at 0.85 kg/litre (7.1 lbs/U.S. gal).

Power output curves are based on the engine operating with fuel system, water pump and lubricating oil pump; not included are battery charging alternator, fan, optional equipment and driven components.

DK. Inueblood

CERTIFIED WITHIN 5%

CHIEF ENGINEER

POWER RATING APPLICATION GUIDELINES FOR GENERATOR DRIVE ENGINES

These guidelines have been formulated to ensure proper application of generator drive engines in A.C. generator set installations. Generator drive engines are not designed for and shall not be used in variable speed D.C. generator set applications.

STANDBY POWER RATING is applicable for supplying emergency power for the duration of the utility power outage. No overload capability is available for this rating. Under no condition is an engine allowed to operate in parallel with the public utility at the Standby Power rating.

> This rating should be applied where reliable utility power is available. A standby rated engine should be sized for a maximum of an 80% average load factor and 200 hours of operation per year. This includes less than 25 hours per year at the Standby Power rating. Standby ratings should never be applied except in true emergency power outages. Negotiated power outages contracted with a utility company are not considered an emergency.

<u>CONTINUOUS POWER RATING</u> is applicable for supplying utility power at a constant 100% load for an unlimited number of hours per year. No overload capability is available for this rating. <u>PRIME POWER RATING</u> is applicable for supplying electric power in lieu of commercially purchased power. Prime Power applications must be in the form of one of the following two categories:

UNLIMITED TIME RUNNING PRIME POWER

Prime Power is available for an unlimited number of hours per year in a variable load application. Variable load should not exceed a 70% average of the Prime Power rating during any operating period of 250 hours.

The total operating time at 100% Prime Power shall not exceed 500 hours per year.

A 10% overload capability is available for a period of 1 hour within a 12 hour period of operation. Total operating time at the 10% overload power shall not exceed 25 hours per year.

LIMITED TIME RUNNING PRIME POWER

Prime Power is available for a limited number of hours in a non-variable load application. It is intended for use in situations where power outages are contracted, such as in utility power curtailment. Engines may be operated in parallel to the public utility up to 750 hours per year at power levels never to exceed the Prime Power rating. The customer should be aware, however, that the life of any engine will be reduced by this constant high load operation. Any operation exceeding 750 hours per year at the Prime Power rating should use the Continuous Power rating.

Reference Standards:

BS-5514 and DIN-6271 standards are based on ISO-3046.

Operation At Elevated Temperature And Altitude:

The engine may be operated at:

1800 RPM up to 5,000 ft (1500 m) and 104° F (40° C) without power deration.

1500 RPM up to 3,300 ft (1000 m) and 104 $^{\rm o}$ F (40 $^{\rm o}$ C) without power deration.

For sustained operation above these conditions, derate by 4% per 1,000 ft (300 m), and 1% per 10° F (2% per 11° C).

Cummins Engir	ne Company, Inc.		
•	Data Sheet	DATA SH	IEET : DS-4212-A
ENGINE MODEL : KTA19-G4 CONFIGURATION NU	MBER : D193091DX02		DATE: 09Dec98 JRVE: FR-4212
INSTALLATION DIAGRAM Fan to Flywheel : 3003983 Heat Exchanger Cooled :	CPL NUMBER • Engine Critical Parts List	: 4153	
GENERAL ENGINE DATA			
Туре			6 Cylinder Diesel
Aspiration		Turbocharged a	and Aftercooled
Bore x Stroke	· · · · · · · · · · · · · · · · · · ·	6.25 x 6.25 (159	x 159)
Displacement	— in ³ (liter)	1150 (18.9)	
Compression Ratio		13.9 : 1	
Dry Weight			<i>(</i> , , , , , , , , , , , , , , , , , , ,
Fan to Flywheel Engine		4085	(1855)
Heat Exchanger Cooled Engine	— lb (kg)	4572	(2076)
Wet Weight			
Fan to Flywheel Engine		4245	(1927)
Heat Exchanger Cooled Engine	— lb (kg)	4808	(2183)
Moment of Inertia of Rotating Components	16 - 642/(1-3) - 322	170	(7.0)
• with FW 4001 Flywheel		170	(7.2)
• with FW 4006 Flywheel		199	(8.4)
Center of Gravity from Rear Face of Flywheel Housing (FH 4018)	. ,	28.4	(721)
Center of Gravity above Crankshaft Centerline		9.0	(229)
Maximum Static Loading at Rear Main Bearing	— ID (кд)	2000	(908)
ENGINE MOUNTING Maximum Bending Moment at Rear Face of Block	— lb • ft (N • m)	1000	(1356)
EXHAUST SYSTEM			
Maximum Back Pressure at Standby Power Rating	— in Hg (mm Hg)	3	(76)
AIR INDUCTION SYSTEM			
Maximum Intake Air Restriction			
with Dirty Filter Element	- in H ₂ O (mm H ₂ O)	25	(635)
with Normal Duty Air Cleaner and Clean Filter Element		10	(254)
with Heavy Duty Air Cleaner and Clean Filter Element		15	(381)
COOLING SYSTEM			
Coolant Capacity — Engine Only		8.0	(30)
— with HX 4073 Heat Exchanger	— US gal (liter)	17.5	(66)
Maximum Coolant Friction Head External to Engine — 1800 rpm	— psi (kPa)	10	(69)
	— psi (kPa)	8	(55)
Maximum Static Head of Coolant Above Engine Crank Centerline		60	(18.3)
Standard Thermostat (Modulating) Range		180 - 200	(82 - 93)
Minimum Pressure Cap		10	(69)
Maximum Top Tank Temperature for Standby / Prime Power		220/212	(104 / 100)
Minimum Raw Water Flow @ 90°F to HX 4073 Heat Exchanger		54	(204)
Maximum Raw Water Inlet Pressure at HX 4073 Heat Exchanger		50	(345)
			()
LUBRICATION SYSTEM			
Oil Pressure @ Idle Speed	— psi (kPa)	20	(138)
@ Governed Speed	— psi (kPa)	50 - 70	(345 - 483)
Maximum Oil Temperature		250	(121)
Oil Capacity with OP 4019 Oil Pan : High - Low		10 - 8.5	(38 - 32)
Total System Capacity (Including Bypass Filter)		13.2	(50)
Angularity of OP 4019 Oil Pan — Front Down			30°
— Front Up			30°
— Side to Side			30°

FUEL SYSTEM

FUEL SYSTEM				
Type Injection System	Direct Injection Cummins PT			
Maximum Restriction at I	PT Fuel Injection Pump — with Clean Fuel Filter		4.0	(102)
	— with Dirty Fuel Filter		8.0	(203)
Maximum Allowable Hea	d on Injector Return Line (Consisting of Friction Head and Static Head)	. — in Hg (mm Hg)	6.5	(165)
Maximum Fuel Flow to Ir	ijection Pump –	– US gph (liter / hr)	58	(220)
ELECTRICAL SYST	EM			
Cranking Motor (Heavy D	Duty, Positive Engagement)	— volt	24	
	, Negative Ground		35	
	istance of Cranking Circuit		0.002	
Minimum Recommended				
 Cold Soak @ 50 °F 	(10 °C) and Above	— 0°F CCA	600	
	to 50 °F (0 °C to 10 °C)		640	
 Cold Soak @ 0 °F to 	o 32 °F (-18 °C to 0 °C)	— 0°F CCA	900	
	BILITY erature for Aided (with Coolant Heater) Cold Start within 10 seconds erature for Unaided Cold Start		50 32	(10) (0)
PERFORMANCE DA	TA			
All data is based on:	 Engine operating with fuel system, water pump, lubricating oil pump, air cle silencer; not included are battery charging alternator, fan, and optional drive Engine operating with fuel corresponding to grade No. 2-D per ASTM D975 ISO 3046, Part 1, Standard Reference Conditions of: Barometric Pressure : 100 kPa (29.53 in Hg) Air Temperature 	en components. 5. re : 25 °C (77	°F)	
	Altitude : 110 m (361 ft) Relative Humin	dity : 30%		
Steady State Stability Band at any Constant Load				0.25
Excludes Exhaust No	91 / 89			

	60 hz		ANDBY 50 hz		PRIME 60 hz		POWER 50 hz		
Governed Engine Speed rpm		1800		1500		1800		1500	
Engine Idle Speed — rpm	Speed — rpm 675 - 775		675 - 775		675 - 775		675 - 775		
Gross Engine Power Output BHP (kW _m)	755	(563)	675	(504)	680	(507)	600	(448)	
Brake Mean Effective Pressure psi (kPa)	287	(1979)	310	(2137)	260	(1793)	275	(1896)	
Piston Speed ft / min (m / s)	1875	(9.5)	1562	(7.9)	1875	(9.5)	1562	(7.9)	
Friction Horsepower — HP (kW _m)	85	(63)	60	(45)	85	(63)	60	(45)	
Engine Water Flow at Stated Friction Head External to Engine:									
• 3 psi Friction Head — US gpm (liter / s)	196	(12.4)	162	(10.2)	196	(12.4)	162	(10.2)	
Maximum Friction Head US gpm (liter / s)	175	(11.0)	145	(9.1)	175	(11.0)	145	(9.1)	
Engine Data with Dry Type Exhaust Manifold									
Intake Air Flow — cfm (liter / s)	1517	(716)	1226	(579)	1455	(687)	1126	(532)	
Exhaust Gas Temperature • °F (°C)	939	(504)	1034	(557)	898	(481)	1000	(538)	
Exhaust Gas Flow cfm (liter / s)	3945	(1862)	3400	(1604)	3673	(1734)	3100	(1463)	
to Fuel Ratio — air : fuel		25.5:1		22.5:1		27.2:1		23.2:1	
Radiated Heat to Ambient BTU / min (kW _m)	4700	(83)	4100	(72)	4200	(74)	3645	(64)	
Heat Rejection to Coolant BTU / min (kWm)	16350	(287)	15340	(270)	14350	(252)	13660	(240)	
Heat Rejection to Exhaust BTU / min (kWm)	24000	(423)	20530	(361)	21500	(378)	18125	(319)	

N.A. - Data is Not Available

N/A - Not Applicable to this Engine

TBD - To Be Determined

CUMMINS ENGINE COMPANY, INC.

Columbus, Indiana 47202-3005